

EC CERTIFICATE OF CONFORMITY

0359-CPD-0110

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

Autronica Fire and Security non integrated PSE models BPS-405 and BPS-410
(refer to attached appendix for details and conditions)

placed on the market by:

Autronica Fire and Security AS
Haakon VII's gt 4, NO-7483 Trondheim, Norway

and produced in the factory by:

Autronica Fire and Security AS
Haakon VII's gt 4, NO-7483 Trondheim, Norway

Is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the notified body No. **0359 - Intertek Testing & Certification Ltd** – has performed the initial type- testing for the relevant characteristics of the product, the initial inspection of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the product performance described in Annex ZA of the product standards

EN 54-4:1998, incorporating amendments A1 and A2
- Power Supply Equipment

were applied and that the product fulfils all the prescribed requirements.

This certification was issued on **17 February 2011** and remains valid as long as the conditions laid down in the harmonised technical specification above, or the product design, or the manufacturing conditions in the factory, or the FPC itself are not modified significantly and latest on **17 February 2016**.



Daniel Griffin - Certification Officer

Appendix to EC Certificate of Conformity 0359-CPD-0110

The details and condition of use for the Autronica Fire and Security non integrated PSE models BPS-405 and BPS-410 placed on the market by:

Autronica Fire and Security AS
Haakon Vlls gt 4, NO-7483 Trondheim, Norway

To be used in accordance with the supplier's installation instructions (*where applicable*):

Conditions of use

General Notes:

1. Tested under DNV report numbers 2010-3386 (EN54-4) and 2010-3355 (EMC)
2. Tested and for use with battery type FG21803
3. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.

This certification was issued on **17 February 2011** and remains valid as long as the conditions laid down in the harmonised technical specification above, or the product design, or the manufacturing conditions in the factory, or the FPC itself are not modified significantly and latest on **17 February 2016**.



Daniel Griffin – Certification Officer