



# CERTIFICATE OF CONSTANCY OF PERFORMANCE

0470 - CPR - 0037

In compliance with Regulation 305/2011/EU of the European Parliament and the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to construction products

## Fire brigade/information panels

Product	Brand	Type
Fire brigade panel	Autronica	BU-110
Information panel	Autronica	BV-110
Alarm Storing Panel	Autronica	BU-111

produced by and in the factory of:  
**Autronica Fire and Security AS**  
**Haakon VII's gate 4**  
**NO-7041 Trondheim, Norway**

This certificate attest that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standards

**EN 54-2:1997/AC:1999/A1:2006**  
**EN 54-17:2005/AC:2007**

under system 1 are applied and that the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 16. May 2014 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the factory are not modified significantly.

Oslo, 10. October 2016

Notified Body Id. no. 0470  
Nemko AS  
P.O. Box 73 Blindern  
NO-0314 Oslo, Norway

Elisabeth Søvik  
Nemko AS