



The manufacturer may use the mark:



Revision 2.3 April 29, 2019  
Surveillance Audit Due  
May 1, 2022



ISO/IEC 17065  
PRODUCT CERTIFICATION BODY  
#1004

# Certificate / Certificat Zertifikat / 合格証

AUT 1409202 C002

*exida* hereby confirms that the:

## **HC800 Infrared Gas Detector Autronica Fire and Security AS Trondheim - Norway**

Has been assessed per the relevant requirements of:

**IEC 61508 : 2010 Parts 1-7**

and meets requirements providing a level of integrity to:

**Systematic Capability: SC 2 (SIL 2 Capable)**

**Random Capability: Type B Element**

**SIL 2 @ HFT=0; Route 2<sub>H</sub>**

**PFD<sub>avg</sub> and Architecture Constraints  
must be verified for each application**

### **Safety Function:**

The line of sight infrared Gas Detection System will sense gas concentrations present between the transmitter and receiver components, and signal an alarm on the 4-20mA output (mA output only model), or one or both of the optional Alarm relay outputs, to indicate the potentially dangerous condition (mA output with optional relay model)

### **Application Restrictions:**

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.



*John C Yozallinas*  
Evaluating Assessor

*[Signature]*

Certifying Assessor

AUT 1409202 C002

**Systematic Capability: SC 2 (SIL 2 Capable)**

**Random Capability: Type B Element**

**SIL 2 @ HFT=0; Route 2<sub>H</sub>**

**PFD<sub>avg</sub> and Architecture Constraints  
must be verified for each application**

HC800 Infrared  
Gas Detector

**Systematic Capability:**

The Product has met manufacturer design process requirements of Safety Integrity Level (SIL) 2. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

**Random Capability:**

The SIL limit imposed by the Architectural Constraints must be met for each element. This element meets *exida* criteria for Route 2<sub>H</sub>.

**IEC 61508 Failure Rates in FIT\***

Application/Device/Configuration	$\lambda_{SD}$	$\lambda_S$	$\lambda_{DD}$	$\lambda_{DU}$
HC800 (mA)	0	76	1142	47
HC800 (Relay)	336	74	755	101

\* FIT = 1 failure / 10<sup>9</sup> hours

**SIL Verification:**

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFD<sub>avg</sub> considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

**Assessment Report:** DET 14-09-202 R001 V2R2 (or later)

**Safety Manual:** 95-8749-1.1 and later



80 N Main St  
Sellersville, PA 18960