



CERTIFICATE



Certificate No. P 15812-61508

Order No. 15811

Applicant Autronica Fire and Security AS
7483 Trondheim, Norway

Manufacturer Autronica Fire and Security AS
7483 Trondheim
Norway

Factory Autronica Fire and Security AS
7483 Trondheim
Norway

Model/type Integrated fire and gas (IFG) system version 3.6.
System to detect fire situations by means of fire, smoke and heat sensors and system to detect gas.

Data 220-240V AC 50/60Hz

Other specification

The above product is certified according to the following standard(s) Safety std.: **IEC 61508:2000** series, part 1 to 7
Functional safety of electrical/electronic/programmable electronic safety-related systems

Safety Integrity Levels The above mentioned system has the capability of SIL 1 and SIL 2 for safety related applications according to: IEC 61508:2000 series

Validity This certificate documents conformity with the standards shown. The certificate and license is valid as long as the applicable conditions are complied with. New standards or amendments to the standards may imply that the product design must be updated and/or that re-testing and re-certification is necessary.

Report Report no 2051 Updated January 2007

Date of issue 18th of January 2007

Signature
Thor Myklebust
Nemko Trondheim

Signature
Terje Johansen
Nemko Trondheim

Nemko AS
P.O. Box 73, Blindern
N-0314 Oslo, Norway

Head Office address
Gaustadalléen 30
Oslo

Telephone
+47 22 96 03 30
Enterprise number:

Fax
+47 22 96 05 50
NO 974404532