


EN



# MANUFACTURER'S DECLARATION OF CONFORMITY



FOR

**Product identification:**

Model/type: Refer to model listing Initial year affixing CE Mark: 2020  
 Category (description): Fire detection and fire alarm systems  
 Brand: Autronica

**Manufacturer:** Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim  
 Norway

**EU Representative:** --

Concerning	A sample of the product has been tested by	Test report reference	Applied standards
EMC	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN 61000-6-3:2007+A1:2011+AC:2012 EN 50130-4:2011
CPR	Intertek Deutschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen, Germany	Certificate: 0905-CPR-00840	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010
MED	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: MEDB00006DJ MEDB0000646	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010 IEC 60092-504:2016 IEC 60533:2015
ATEX	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: DNV 21ATEX14779X (V-530-EXIA) DNV 22ATEX13772X (V-530-EXIC)	EN IEC 60079-0:2018 EN 60079-11:2012
RoHS	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN IEC 63000:2018

**Restrictions on putting into service / requirements for authorization of use**

Not Applicable       None       

**Means of conformity**


We declare under our sole responsibility that this product is in conformity with Directives: 93/68/EEC (Marking), 2014/30/EU (EMC), 305/2011 (CPR), 2014/90/EU (MED), 2014/34/EU (ATEX), (and 2011/65/EU (RoHS) amended by 2015/863 and 2017/2102, and complies with the essential requirements and all other relevant provisions of the Directives based on test results using harmonized standards in accordance with the Directives mentioned.


Signature of representative / manufacturer:



Tomasz Dowgiałło, Compliance Leader  
 Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim, Norway

**ATEX:**

V-530-EXIA:  II 1 G Ex ia IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

V-530-EXIC:  II 3 G Ex ic IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

**Model listing** (List of all product variants or models for which this declaration is valid)

Model	Description
V-430-S	Multicriteria Detector with Sounder
V-530-S	Multicriteria Detector SIL2 with Sounder
V-430-VADW	Multicriteria Detector with White Beacon
V-530-VADW	Multicriteria Detector SIL2 with White Beacon
V-430-S-VADW	Multicriteria Detector with Sounder and White Beacon
V-530-S-VADW	Multicriteria SIL2 Detector with Sounder and White Beacon
V-430-SP	Multicriteria Detector with Speech
V-530-SP	Multicriteria Detector SIL2 with Speech
V-430-SP-VADW	Multicriteria Detector with Speech and White Beacon
V-530-SP-VADW	Multicriteria Detector SIL2 with Speech and White Beacon
V-430-SP-VADR	Multicriteria Detector with Speech and Red Beacon
V-530-SP-VADR	Multicriteria Detector SIL2 with Speech and Red Beacon
V-430-S-VADR	Multicriteria Detector with Sounder and Red Beacon
V-530-S-VADR	Multicriteria Detector SIL2 with Sounder and Red Beacon
V-430-VADR	Multicriteria Detector with Red Beacon
V-530-VADR	Multicriteria Detector SIL2 with Red Beacon
V-430	Multicriteria Detector
V-530	Multicriteria Detector SIL2
V-530-EXIA	Multicriteria Detector with SIL2 Ex ia
V-530-EXIC	Multicriteria Detector with SIL2 Ex ic
<p>Full model codes are defined by the formats V-430-xxxx-yy/ww/zz and V-530-xxxx-yy/ww/zz where:</p> <p>xxxx = Model as listed in the table above:            S, VADW, VADR, S-VADR, SP-VADW, SP-VADR, EXIA, EXIC</p> <p>yy = Color of housing:            Blank = White, BK = Black, CC = Customized Color</p> <p>ww = Enabled options:            Blank = None, CD = Cover Detection &amp; Self Verify, HS = Extra High Sensitivity*, DS = Data Subscription, CFxxx = Custom Features (C = A to Z, F = A to Z, xxx = 000 to 999)</p> <p>* Note that when the HS = Extra High Sensitivity setting is used, the product is not compliant with EN 54-7:2018.</p>	

Signature of representative / manufacturer:




Tomasz Dowgiałło, Compliance Leader  
 Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim, Norway

CZ



# PROHLÁŠENÍ VÝROBCE O SHODĚ

PRO



## Identifikace produktu:

Model/typ: Viz Seznam modelů První rok přidělení označení CE: 2020

Kategorie (popis): Fire detection and fire alarm systems


Značka: Autronica

Výrobce: Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim  
Norway

Zástupce pro EU: --

Ve věci	Vzorek produktu byl testován společností	Reference protokolu o testování	Použití normy
EMC	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN 61000-6-3:2007+A1:2011+AC:2012 EN 50130-4:2011
CPR	Intertek Deatschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen, Germany	Certificate: 0905-CPR-00840	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010
MED	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: MEDB00006DJ MEDB0000646	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010 IEC 60092-504:2016 IEC 60533:2015
ATEX	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: DNV 21ATEX14779X (V-530-EXIA) DNV 22ATEX13772X (V-530-EXIC)	EN IEC 60079-0:2018 EN 60079-11:2012
RoHS	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN IEC 63000:2018


## Omezení pro uvádění do provozu / požadavky na povolení k používání

Nevztahuje se  Žádné  

## Způsob zajištění shody

Na vlastní odpovědnost prohlašujeme, že tento produkt splňuje požadavky následujících směrnic: 93/68/EEC (značení), 2014/30/EU (EMC), 305/2011 (CPR), 2014/34/EU (ATEX), 2014/90/EU (MED), a 2011/65/EU (RoHS), ve znění 2015/863 a 2017/2102, a splňuje základní požadavky a všechna další příslušná ustanovení směrnic na základě výsledků testů při použití harmonizovaných norem v souladu s uvedenými směrnicemi.

## ATEX:

V-530-EXIA:  II 1 G Ex ia IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

Podpis zástupce/výrobce:



Tomasz Dowgiałło, vedoucí pro zajištění souladu  
Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim, Norway

V-530-EXIC:



II 3 G Ex ic IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

**Seznam modelů** (seznam všech variant nebo modelů produktů, pro které je toto prohlášení platné):

Model	Popis
V-430-S	Multicriteria Detector with Sounder
V-530-S	Multicriteria Detector SIL2 with Sounder
V-430-VADW	Multicriteria Detector with White Beacon
V-530-VADW	Multicriteria Detector SIL2 with White Beacon
V-430-S-VADW	Multicriteria Detector with Sounder and White Beacon
V-530-S-VADW	Multicriteria SIL2 Detector with Sounder and White Beacon
V-430-SP	Multicriteria Detector with Speech
V-530-SP	Multicriteria Detector SIL2 with Speech
V-430-SP-VADW	Multicriteria Detector with Speech and White Beacon
V-530-SP-VADW	Multicriteria Detector SIL2 with Speech and White Beacon
V-430-SP-VADR	Multicriteria Detector with Speech and Red Beacon
V-530-SP-VADR	Multicriteria Detector SIL2 with Speech and Red Beacon
V-430-S-VADR	Multicriteria Detector with Sounder and Red Beacon
V-530-S-VADR	Multicriteria Detector SIL2 with Sounder and Red Beacon
V-430-VADR	Multicriteria Detector with Red Beacon
V-530-VADR	Multicriteria Detector SIL2 with Red Beacon
V-430	Multicriteria Detector
V-530	Multicriteria Detector SIL2
V-530-EXIA	Multicriteria Detector with SIL2 Ex ia
V-530-EXIC	Multicriteria Detector with SIL2 Ex ic
<p>Full model codes are defined by the formats V-430-xxxxx-yy/ww/zz and V-530-xxxxx-yy/ww/zz where:</p> <p>xxxxx = Model as listed in the table above: S, VADW, VADR, S-VADR, SP-VADW, SP-VADR, EXIA, EXIC</p> <p>yy = Color of housing: Blank = White, BK = Black, CC = Customized Color</p> <p>ww = Enabled options: Blank = None, CD = Cover Detection &amp; Self Verify, HS = Extra High Sensitivity*, DS = Data Subscription, CFxxx = Custom Features (C = A to Z, F = A to Z, xxx = 000 to 999)</p> <p>* Note that when the HS = Extra High Sensitivity setting is used, the product is not compliant with EN 54-7:2018.</p>	

Podpis zástupce/výrobce:




Tomasz Dowgiałło, vedoucí pro zajištění souladu  
Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim, Norway

DA



# PRODUCENTENS OVERENSSTEMMELSESERKLÆRING



FOR

**Produktidentifikation:**


Model/type: Se modelliste Første år med CE-mærke: 2020  
 Kategori (beskrivelse): Fire detection and fire alarm systems  
 Mærke: Autronica

**Producent:** Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim  
 Norway

**EU-repræsentant:** --

Angående	En prøve af produktet er blevet testet af:	Testrapportreference	Anvendte standarder
EMC	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN 61000-6-3:2007+A1:2011+AC:2012 EN 50130-4:2011
CPR	Intertek Deatschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen, Germany	Certificate: 0905-CPR-00840	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010
MED	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: MEDB00006DJ MEDB0000646	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010 IEC 60092-504:2016 IEC 60533:2015
ATEX	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: DNV 21ATEX14779X (V-530-EXIA) DNV 22ATEX13772X (V-530-EXIC)	EN IEC 60079-0:2018 EN 60079-11:2012
RoHS	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN IEC 63000:2018

**Begrænsninger vedrørende ibrugtagning/krav til godkendelse af brug**

Ikke relevant  Ingen  

**Overensstemmelsesattestation**

Vi erklærer under vores eneansvar, at dette produkt er i overensstemmelse med direktiverne: 93/68/EØF (mærkning), 2014/30/EU (EMC), 305/2011 (CPR), 2014/90/EU (MED), 2014/34/EU (ATEX), og 2011/65/EU (RoHS), ændret ved 2015/863 og 2017/2102, og overholder de væsentlige krav og alle andre bestemmelser i direktiverne baseret på testresultater med brug af harmoniserede standarder i henhold til de nævnte direktiver.

**ATEX:**

V-530-EXIA:  II 1 G Ex ia IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

Repræsentantens/producentens underskrift: Tomasz Dowgiałto, Compliance Leader  
 Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim, Norway



V-530-EXIC:



II 3 G Ex ic IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

**Modelliste** (liste over alle produktvarianter eller -modeller, som denne erklæring gælder for)

Model	Beskrivelse
V-430-S	Multicriteria Detector with Sounder
V-530-S	Multicriteria Detector SIL2 with Sounder
V-430-VADW	Multicriteria Detector with White Beacon
V-530-VADW	Multicriteria Detector SIL2 with White Beacon
V-430-S-VADW	Multicriteria Detector with Sounder and White Beacon
V-530-S-VADW	Multicriteria SIL2 Detector with Sounder and White Beacon
V-430-SP	Multicriteria Detector with Speech
V-530-SP	Multicriteria Detector SIL2 with Speech
V-430-SP-VADW	Multicriteria Detector with Speech and White Beacon
V-530-SP-VADW	Multicriteria Detector SIL2 with Speech and White Beacon
V-430-SP-VADR	Multicriteria Detector with Speech and Red Beacon
V-530-SP-VADR	Multicriteria Detector SIL2 with Speech and Red Beacon
V-430-S-VADR	Multicriteria Detector with Sounder and Red Beacon
V-530-S-VADR	Multicriteria Detector SIL2 with Sounder and Red Beacon
V-430-VADR	Multicriteria Detector with Red Beacon
V-530-VADR	Multicriteria Detector SIL2 with Red Beacon
V-430	Multicriteria Detector
V-530	Multicriteria Detector SIL2
V-530-EXIA	Multicriteria Detector with SIL2 Ex ia
V-530-EXIC	Multicriteria Detector with SIL2 Ex ic
<p>Full model codes are defined by the formats V-430-xxxxx-yy/ww/zz and V-530-xxxxx-yy/ww/zz where:</p> <p>xxxxx = Model as listed in the table above: S, VADW, VADR, S-VADR, SP-VADW, SP-VADR, EXIA, EXIC</p> <p>yy = Color of housing: Blank = White, BK = Black, CC = Customized Color</p> <p>ww = Enabled options: Blank = None, CD = Cover Detection &amp; Self Verify, HS = Extra High Sensitivity*, DS = Data Subscription, CFxxx = Custom Features (C = A to Z, F = A to Z, xxx = 000 to 999)</p> <p>* Note that when the HS = Extra High Sensitivity setting is used, the product is not compliant with EN 54-7:2018.</p>	

Repræsentantens/producentens underskrift:



Tomasz Dowgiałło, Compliance Leader  
Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim, Norway

Sted: Gdańsk, Polen

Dato: 30 september 2022


Side 6 af 40

Dok. Nr.: 60. 1005405

DE



# KONFORMITÄTSERKLÄRUNG DES HERSTELLERS



FÜR

**Produktbezeichnung:**

Modell/Typ: Siehe Modellauflistung Erste Anbringung der CE-Kennzeichnung im Jahr: 2020

Kategorie (Beschreibung): Fire detection and fire alarm systems

Marke: Autronica

**Hersteller:** Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim  
Norway

**EU-Bevollmächtigter:** --

Betr.	Eine Stichprobenprüfung des Produkts wurde durchgeführt von	Bezugnahme auf Prüfbericht	Angewandte Normen
EMC	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN 61000-6-3:2007+A1:2011+AC:2012 EN 50130-4:2011
CPR	Intertek Deutschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen, Germany	Certificate: 0905-CPR-00840	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010
MED	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: MEDB00006DJ MEDB0000646	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010 IEC 60092-504:2016 IEC 60533:2015
ATEX	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: DNV 21ATEX14779X (V-530-EXIA) DNV 22ATEX13772X (V-530-EXIC)	EN IEC 60079-0:2018 EN 60079-11:2012
RoHS	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN IEC 63000:2018

**Beschränkungen der Inbetriebnahme/Anforderungen für die Nutzungsgenehmigung**

Nicht zutreffend       Keine       

**Konformitätsnachweis**

Wir erklären in alleiniger Verantwortung, dass das Produkt folgenden Richtlinien entspricht: 93/68/EWG (Kennzeichnung), 2014/30/EU (EMC), 305/2011 (CPR), 2014/90/EU (MED), 2014/34/EU (ATEX), sowie 2011/65/EU (RoHS), ergänzt durch 2015/863 und 2017/2102. Weiterhin entspricht das Produkt allen grundlegenden Anforderungen und den anderen relevanten Bestimmungen der Richtlinien gemäß der Prüfergebnisse aufgrund harmonisierter Normen in Übereinstimmung mit den hier aufgeführten Richtlinien.

Signatur des Bevollmächtigten/Herstellers:



Tomasz Dowgiałło, Compliance Leader  
Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim, Norway

Ort: Danzig, Polen

Datum: 30 September 2022

Seite 7 von 40

Dok. Nr.: 60. 1005405

**ATEX:**

V-530-EXIA:  II 1 G Ex ia IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

V-530-EXIC:  II 3 G Ex ic IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

**Modellaufistung** (Liste sämtlicher Produktvarianten oder Modelle, für die diese Erklärung gilt)

Modell	Beschreibung
V-430-S	Multicriteria Detector with Sounder
V-530-S	Multicriteria Detector SIL2 with Sounder
V-430-VADW	Multicriteria Detector with White Beacon
V-530-VADW	Multicriteria Detector SIL2 with White Beacon
V-430-S-VADW	Multicriteria Detector with Sounder and White Beacon
V-530-S-VADW	Multicriteria SIL2 Detector with Sounder and White Beacon
V-430-SP	Multicriteria Detector with Speech
V-530-SP	Multicriteria Detector SIL2 with Speech
V-430-SP-VADW	Multicriteria Detector with Speech and White Beacon
V-530-SP-VADW	Multicriteria Detector SIL2 with Speech and White Beacon
V-430-SP-VADR	Multicriteria Detector with Speech and Red Beacon
V-530-SP-VADR	Multicriteria Detector SIL2 with Speech and Red Beacon
V-430-S-VADR	Multicriteria Detector with Sounder and Red Beacon
V-530-S-VADR	Multicriteria Detector SIL2 with Sounder and Red Beacon
V-430-VADR	Multicriteria Detector with Red Beacon
V-530-VADR	Multicriteria Detector SIL2 with Red Beacon
V-430	Multicriteria Detector
V-530	Multicriteria Detector SIL2
V-530-EXIA	Multicriteria Detector with SIL2 Ex ia
V-530-EXIC	Multicriteria Detector with SIL2 Ex ic
<p>Full model codes are defined by the formats V-430-xxxx-yy/ww/zz and V-530-xxxx-yy/ww/zz where:</p> <p>xxxx = Model as listed in the table above:            S, VADW, VADR, S-VADR, SP-VADW, SP-VADR, EXIA, EXIC</p> <p>yy = Color of housing:            Blank = White, BK = Black, CC = Customized Color</p> <p>ww = Enabled options:            Blank = None, CD = Cover Detection &amp; Self Verify, HS = Extra High Sensitivity*, DS = Data Subscription, CFxxx = Custom Features (C = A to Z, F = A to Z, xxx = 000 to 999)</p> <p>* Note that when the HS = Extra High Sensitivity setting is used, the product is not compliant with EN 54-7:2018.</p>	

Signatur des Bevollmächtigten/Herstellers:




Tomasz Dowgiało, Compliance Leader  
 Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim, Norway



EL



# ΔΗΛΩΣΗ ΣΥΜΜΟΡΦΩΣΗΣ ΤΟΥ ΚΑΤΑΣΚΕΥΑΣΤΗ



ΓΙΑ

## Στοιχεία προϊόντος:

Μοντέλο / Τύπος: Ανατρέξτε στη λίστα μοντέλων

Έτος πρώτης επίθεσης του  
σήματος CE: 2020

Κατηγορία (περιγραφή): Fire detection and fire alarm systems

Επωνυμία: Autronica

**Κατασκευαστής:** Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim  
Norway

**Αντιπρόσωπος στην ΕΕ:** --

Πεδίο	Ένα δείγμα του προϊόντος έχει ελεγχθεί από:	Αρ. αναφοράς ελέγχου	Εφαρμοσμένα πρότυπα
EMC	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN 61000-6-3:2007+A1:2011+AC:2012 EN 50130-4:2011
CPR	Intertek Deutschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen, Germany	Certificate: 0905-CPR-00840	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010
MED	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: MEDB00006DJ MEDB0000646	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010 IEC 60092-504:2016 IEC 60533:2015
ATEX	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: DNV 21ATEX14779X (V-530-EXIA) DNV 22ATEX13772X (V-530-EXIC)	EN IEC 60079-0:2018 EN 60079-11:2012
RoHS	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN IEC 63000:2018

## Περιορισμοί λειτουργίας / απαιτήσεις για έγκριση χρήσης

Δεν ισχύει

Δεν υπάρχουν



## Μέσα συμμόρφωσης

Δηλώνουμε, με δική μας ευθύνη, ότι αυτό το προϊόν συμμορφώνεται με την Οδηγία 93/68/ΕΟΚ (Σήμανση), 2014/30/ΕΕ (EMC), 305/2011 (CPR), 2014/90/ΕΥ (MED), 2014/34/ΕΥ (ATEX), και την Οδηγία 2011/65/ΕΕ (Περιορισμός της χρήσης ορισμένων επικίνδυνων ουσιών σε ηλεκτρικό και ηλεκτρονικό εξοπλισμό), όπως ισχύει τροποποιημένη από τις Οδηγίες 2015/863 και 2017/2102, και συμμορφώνεται με τις ουσιαστικές απαιτήσεις και όλες τις άλλες σχετικές διατάξεις των Οδηγιών με βάση τα αποτελέσματα των δοκιμών που έγιναν με τη χρήση εναρμονισμένων προτύπων, σύμφωνα με τις αναφερόμενες Οδηγίες.

Υπογραφή αντιπροσώπου / κατασκευαστή:



Tomasz Dowgiałło, Compliance Leader  
Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim, Norway

Τόπος: Γκντανσκ, Πολωνία

Ημερομηνία: 30 Σεπτεμβρίου 2022

Σελίδα 9 από 40

Αρ. εγγράφου: 60. 1005405

**ATEX:**

V-530-EXIA:  II 1 G Ex ia IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

V-530-EXIC:  II 3 G Ex ic IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

**Λίστα μοντέλων** (Λίστα με όλες τις εκδόσεις ή τα μοντέλα προϊόντων για τα οποία ισχύει αυτή η δήλωση)

Μοντέλο	Περιγραφή
V-430-S	Multicriteria Detector with Sounder
V-530-S	Multicriteria Detector SIL2 with Sounder
V-430-VADW	Multicriteria Detector with White Beacon
V-530-VADW	Multicriteria Detector SIL2 with White Beacon
V-430-S-VADW	Multicriteria Detector with Sounder and White Beacon
V-530-S-VADW	Multicriteria SIL2 Detector with Sounder and White Beacon
V-430-SP	Multicriteria Detector with Speech
V-530-SP	Multicriteria Detector SIL2 with Speech
V-430-SP-VADW	Multicriteria Detector with Speech and White Beacon
V-530-SP-VADW	Multicriteria Detector SIL2 with Speech and White Beacon
V-430-SP-VADR	Multicriteria Detector with Speech and Red Beacon
V-530-SP-VADR	Multicriteria Detector SIL2 with Speech and Red Beacon
V-430-S-VADR	Multicriteria Detector with Sounder and Red Beacon
V-530-S-VADR	Multicriteria Detector SIL2 with Sounder and Red Beacon
V-430-VADR	Multicriteria Detector with Red Beacon
V-530-VADR	Multicriteria Detector SIL2 with Red Beacon
V-430	Multicriteria Detector
V-530	Multicriteria Detector SIL2
V-530-EXIA	Multicriteria Detector with SIL2 Ex ia
V-530-EXIC	Multicriteria Detector with SIL2 Ex ic
Full model codes are defined by the formats V-430-xxxxx-yy/ww/zz and V-530-xxxxx-yy/ww/zz where: xxxxx = Model as listed in the table above: S, VADW, VADR, S-VADR, SP-VADW, SP-VADR, EXIA, EXIC yy = Color of housing: Blank = White, BK = Black, CC = Customized Color ww = Enabled options: Blank = None, CD = Cover Detection & Self Verify, HS = Extra High Sensitivity*, DS = Data Subscription, CFxxx = Custom Features (C = A to Z, F = A to Z, xxx = 000 to 999) * Note that when the HS = Extra High Sensitivity setting is used, the product is not compliant with EN 54-7:2018.	

Υπογραφή αντιπροσώπου / κατασκευαστή:




Tomasz Dowgiałło, Compliance Leader  
Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim, Norway

ES



# DECLARACIÓN DE CONFORMIDAD DEL FABRICANTE



PARA

**Identificación del producto:**

Tipo de modelo: Consulte la lista de modelos. Año inicial de la inclusión de la marca CE: 2020

Categoría (descripción): Fire detection and fire alarm systems


Marca: Autronica

**Fabricante:** Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim  
Norway

**Representante europeo:** --

En relación con	Responsable de la prueba de la muestra del producto	Informe de referencia de la prueba	Normas aplicadas
<b>EMC</b>	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN 61000-6-3:2007+A1:2011+AC:2012 EN 50130-4:2011
<b>CPR</b>	Intertek Deutschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen, Germany	Certificate: 0905-CPR-00840	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010
<b>MED</b>	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: MEDB00006DJ MEDB0000646	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010 IEC 60092-504:2016 IEC 60533:2015
<b>ATEX</b>	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: DNV 21ATEX14779X (V-530-EXIA) DNV 22ATEX13772X (V-530-EXIC)	EN IEC 60079-0:2018 EN 60079-11:2012
<b>RoHS</b>	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN IEC 63000:2018

**Restricciones de puesta en servicio / requisitos de autorización de uso**

No aplicable  Ninguna  

**Medio de conformidad**

Declaramos, bajo nuestra responsabilidad, que este producto se ha fabricado de acuerdo con la siguientes directivas: 93/68/CEE (marcado); 2014/30/EU (EMC), 305/2011 (CPR), 2014/90/EU (MED), 2014/34/EU (ATEX), y 2011/65/UE (RoHS), corregida por 2015/863 y 2017/2102, y cumple los requisitos básicos y todas las demás disposiciones pertinentes de las directivas según los resultados de las pruebas mediante normas armonizadas de acuerdo con las directivas mencionadas.

Firma del representante / fabricante:



Tomasz Dowgiałło, director de conformidad  
Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim, Norway

**ATEX:**

V-530-EXIA:  II 1 G Ex ia IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

V-530-EXIC:  II 3 G Ex ic IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

**Lista de modelos** (lista de todos los modelos o las variantes de productos para los que esta declaración es válida)

Modelo	Descripción
V-430-S	Multicriteria Detector with Sounder
V-530-S	Multicriteria Detector SIL2 with Sounder
V-430-VADW	Multicriteria Detector with White Beacon
V-530-VADW	Multicriteria Detector SIL2 with White Beacon
V-430-S-VADW	Multicriteria Detector with Sounder and White Beacon
V-530-S-VADW	Multicriteria SIL2 Detector with Sounder and White Beacon
V-430-SP	Multicriteria Detector with Speech
V-530-SP	Multicriteria Detector SIL2 with Speech
V-430-SP-VADW	Multicriteria Detector with Speech and White Beacon
V-530-SP-VADW	Multicriteria Detector SIL2 with Speech and White Beacon
V-430-SP-VADR	Multicriteria Detector with Speech and Red Beacon
V-530-SP-VADR	Multicriteria Detector SIL2 with Speech and Red Beacon
V-430-S-VADR	Multicriteria Detector with Sounder and Red Beacon
V-530-S-VADR	Multicriteria Detector SIL2 with Sounder and Red Beacon
V-430-VADR	Multicriteria Detector with Red Beacon
V-530-VADR	Multicriteria Detector SIL2 with Red Beacon
V-430	Multicriteria Detector
V-530	Multicriteria Detector SIL2
V-530-EXIA	Multicriteria Detector with SIL2 Ex ia
V-530-EXIC	Multicriteria Detector with SIL2 Ex ic
<p>Full model codes are defined by the formats V-430-xxxxx-yy/ww/zz and V-530-xxxxx-yy/ww/zz where:</p> <p>xxxxx = Model as listed in the table above:            S, VADW, VADR, S-VADR, SP-VADW, SP-VADR, EXIA, EXIC</p> <p>yy = Color of housing:            Blank = White, BK = Black, CC = Customized Color</p> <p>ww = Enabled options:            Blank = None, CD = Cover Detection &amp; Self Verify, HS = Extra High Sensitivity*, DS = Data Subscription, CFxxx = Custom Features (C = A to Z, F = A to Z, xxx = 000 to 999)</p> <p>* Note that when the HS = Extra High Sensitivity setting is used, the product is not compliant with EN 54-7:2018.</p>	

Firma del representante / fabricante:




Tomasz Dowgiałło, director de conformidad  
 Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim, Norway

ET



# TOOTJA VASTAVUSDEKLARATSIOON



**Toote andmed:**

Mudel/tüüp: Vaadake mudeli loendit Esimene CE-vastavusmärgise kinnitamise aasta: 2020  
 Kategooria (kirjeldus): Fire detection and fire alarm systems  
 Tootemark: Autronica

**Tootja:** Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim  
 Norway

**ELi esindaja:** --

Mille suhtes	Toote proovi on katsetanud	Katsearuande viide	Rakendatud standardid
<b>EMC</b>	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN 61000-6-3:2007+A1:2011+AC:2012 EN 50130-4:2011
<b>CPR</b>	Intertek Deutschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen, Germany	Certificate: 0905-CPR-00840	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010
<b>MED</b>	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: MEDB00006DJ MEDB0000646	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010 IEC 60092-504:2016 IEC 60533:2015
<b>ATEX</b>	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: DNV 21ATEX14779X (V-530-EXIA) DNV 22ATEX13772X (V-530-EXIC)	EN IEC 60079-0:2018 EN 60079-11:2012
<b>RoHS</b>	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN IEC 63000:2018

**Kasutusele võtmise piirangud / kasutusloa nõuded**

Ei ole kohaldatav  Puudub  

**Vastavusmeetmed**

Kinnitame ainuisikuliselt, et see toode vastab direktiividele: 93/68/EMÜ (märgistus), 2014/30/EL (EMC), 305/2011 (CPR), 2014/90/EU (MED), 2014/34/EU (ATEX), ja 2011/65/EL (ohtlike ainete kasutamise piiramise direktiiv, RoHS), mida on muudetud direktiividega 2015/863 ja 2017/2102, ning vastab direktiivide põhioletetele ja kõigile muudele asjakohastele sätetele, mis põhinevad katsetulemustel, kasutades nimetatud direktiividele vastavaid ühtlustatud standardeid.

**ATEX:**

V-530-EXIA:  II 1 G Ex ia IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

Esindaja/tootja allkiri:



Tomasz Dowgiałło, vastavusjuht  
 Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim, Norway

V-530-EXIC:



II 3 G Ex ic IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

**Mudelite loend** (kõigi tootevariantide või -mudelite loetelu, mille puhul see deklaratsioon kehtib)

Mudel	Kirjeldus
V-430-S	Multicriteria Detector with Sounder
V-530-S	Multicriteria Detector SIL2 with Sounder
V-430-VADW	Multicriteria Detector with White Beacon
V-530-VADW	Multicriteria Detector SIL2 with White Beacon
V-430-S-VADW	Multicriteria Detector with Sounder and White Beacon
V-530-S-VADW	Multicriteria SIL2 Detector with Sounder and White Beacon
V-430-SP	Multicriteria Detector with Speech
V-530-SP	Multicriteria Detector SIL2 with Speech
V-430-SP-VADW	Multicriteria Detector with Speech and White Beacon
V-530-SP-VADW	Multicriteria Detector SIL2 with Speech and White Beacon
V-430-SP-VADR	Multicriteria Detector with Speech and Red Beacon
V-530-SP-VADR	Multicriteria Detector SIL2 with Speech and Red Beacon
V-430-S-VADR	Multicriteria Detector with Sounder and Red Beacon
V-530-S-VADR	Multicriteria Detector SIL2 with Sounder and Red Beacon
V-430-VADR	Multicriteria Detector with Red Beacon
V-530-VADR	Multicriteria Detector SIL2 with Red Beacon
V-430	Multicriteria Detector
V-530	Multicriteria Detector SIL2
V-530-EXIA	Multicriteria Detector with SIL2 Ex ia
V-530-EXIC	Multicriteria Detector with SIL2 Ex ic
<p>Full model codes are defined by the formats V-430-xxxx-yy/ww/zz and V-530-xxxx-yy/ww/zz where:</p> <p>xxxx = Model as listed in the table above:            S, VADW, VADR, S-VADR, SP-VADW, SP-VADR, EXIA, EXIC</p> <p>yy = Color of housing:            Blank = White, BK = Black, CC = Customized Color</p> <p>ww = Enabled options:            Blank = None, CD = Cover Detection &amp; Self Verify, HS = Extra High Sensitivity*, DS = Data Subscription, CFxxx = Custom Features (C = A to Z, F = A to Z, xxx = 000 to 999)</p> <p>* Note that when the HS = Extra High Sensitivity setting is used, the product is not compliant with EN 54-7:2018.</p>	

Esindaja/tootja allkiri:




Tomasz Dowgiałło, vastavusjuht  
 Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim, Norway

FI



# VALMISTAJAN VAATIMUSTENMUKAISUUSVAKUUTUS



TUOTTEELLE

**Tuotetunnus:**

Malli/tyyppi: Katso malliluettelo CE-merkinnän alkuperäinen kiinnitysvuosi: 2020  
 Luokka (kuvaus): Fire detection and fire alarm systems  
 Tuotemerkki: Autronica

**Valmistaja:**

Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim  
 Norway

**Edustaja EU:ssa:**

--

Koskien direktiiviä	Tuotteen näytekappaleen on testannut	Testiraporttiviite	Sovellettavat standardit
EMC	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN 61000-6-3:2007+A1:2011+AC:2012 EN 50130-4:2011
CPR	Intertek Deatschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen, Germany	Certificate: 0905-CPR-00840	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010
MED	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: MEDB00006DJ MEDB0000646	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010 IEC 60092-504:2016 IEC 60533:2015
ATEX	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: DNV 21ATEX14779X (V-530-EXIA) DNV 22ATEX13772X (V-530-EXIC)	EN IEC 60079-0:2018 EN 60079-11:2012
RoHS	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN IEC 63000:2018

**Käyttöönottoa koskevat rajoitukset / käytön sallimisen edellytykset**

Ei sovellu

Ei ole



**Vaatimustenmukaisuus**

Vakuutamme yksinomaisella vastuullamme, että tämä tuote on seuraavien direktiivien mukainen: 93/68/EEC (merkintä), 2014/30/EU (EMC), 305/2011 (CPR), 2014/90/EU (MED), 2014/34/EU (ATEX), ja 2011/65/EU (RoHS) jota on muutettu direktiiveillä 2015/863 ja 2017/2102. Vakuutamme, että tuote on direktiivien olennaisten vaatimusten ja kaikkien muiden olennaisten määräysten mukainen perustuen tuloksiin testeistä, joissa on käytetty yhdenmukaistettuja standardeja mainittujen direktiivien mukaisesti.

Edustajan/valmistajan allekirjoitus:



Tomasz Dowgiałło, vaatimustenmukaisuusjohtaja  
 Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim, Norway

**ATEX:**

V-530-EXIA:  II 1 G Ex ia IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

V-530-EXIC:  II 3 G Ex ic IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

**Malliluettelo** (luettelo kaikista tuoteversioista tai -malleista, joita tämä vakuutus koskee)

Malli	Kuvaus
V-430-S	Multicriteria Detector with Sounder
V-530-S	Multicriteria Detector SIL2 with Sounder
V-430-VADW	Multicriteria Detector with White Beacon
V-530-VADW	Multicriteria Detector SIL2 with White Beacon
V-430-S-VADW	Multicriteria Detector with Sounder and White Beacon
V-530-S-VADW	Multicriteria SIL2 Detector with Sounder and White Beacon
V-430-SP	Multicriteria Detector with Speech
V-530-SP	Multicriteria Detector SIL2 with Speech
V-430-SP-VADW	Multicriteria Detector with Speech and White Beacon
V-530-SP-VADW	Multicriteria Detector SIL2 with Speech and White Beacon
V-430-SP-VADR	Multicriteria Detector with Speech and Red Beacon
V-530-SP-VADR	Multicriteria Detector SIL2 with Speech and Red Beacon
V-430-S-VADR	Multicriteria Detector with Sounder and Red Beacon
V-530-S-VADR	Multicriteria Detector SIL2 with Sounder and Red Beacon
V-430-VADR	Multicriteria Detector with Red Beacon
V-530-VADR	Multicriteria Detector SIL2 with Red Beacon
V-430	Multicriteria Detector
V-530	Multicriteria Detector SIL2
V-530-EXIA	Multicriteria Detector with SIL2 Ex ia
V-530-EXIC	Multicriteria Detector with SIL2 Ex ic
Full model codes are defined by the formats V-430-xxxx-yy/ww/zz and V-530-xxxx-yy/ww/zz where: xxxx = Model as listed in the table above: S, VADW, VADR, S-VADR, SP-VADW, SP-VADR, EXIA, EXIC yy = Color of housing: Blank = White, BK = Black, CC = Customized Color ww = Enabled options: Blank = None, CD = Cover Detection & Self Verify, HS = Extra High Sensitivity*, DS = Data Subscription, CFxxx = Custom Features (C = A to Z, F = A to Z, xxx = 000 to 999) * Note that when the HS = Extra High Sensitivity setting is used, the product is not compliant with EN 54-7:2018.	

Edustajan/valmistajan allekirjoitus:




Tomasz Dowgiałło, vaatimustenmukaisuusjohtaja  
Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim, Norway



FR



# DÉCLARATION DE CONFORMITÉ DU FABRICANT



POUR

**Identification du produit :**

Modèle/type : Voir la liste des modèles Année initiale en regard du symbole CE : 2020

Catégorie (description) : Fire detection and fire alarm systems

Marque : Autronica

**Fabricant :** Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim  
Norway

**Représentant UE :** --

Concernant	Un échantillon du produit a été testé par	Référence du rapport de test	Normes appliquées
<b>EMC</b>	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN 61000-6-3:2007+A1:2011+AC:2012 EN 50130-4:2011
<b>CPR</b>	Intertek Deutschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen, Germany	Certificate: 0905-CPR-00840	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010
<b>MED</b>	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: MEDB00006DJ MEDB0000646	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010 IEC 60092-504:2016 IEC 60533:2015
<b>ATEX</b>	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: DNV 21ATEX14779X (V-530-EXIA) DNV 22ATEX13772X (V-530-EXIC)	EN IEC 60079-0:2018 EN 60079-11:2012
<b>RoHS</b>	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN IEC 63000:2018

**Restrictions de mise en service/exigences avant autorisation d'usage**

Non applicable

Aucune



**Mesures de conformité**

Nous déclarons sous notre seule responsabilité que ce produit est conforme aux directives 93/68/EEC (Marquage), 2014/30/EU (EMC), 305/2011 (CPR), 2014/90/EU (MED), 2014/34/EU (ATEX), et 2011/65/EU (RoHS), modifiée par les directives 2015/863 et 2017/2102, et est conforme aux exigences essentielles et autres dispositions pertinentes des directives en fonction des résultats de test obtenus à l'aide de normes harmonisées, conformément aux directives concernées.

Signature du représentant/fabricant :



Tomasz Dowgiałło, Chargé de la conformité  
Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim, Norway

**ATEX:**

V-530-EXIA:  II 1 G Ex ia IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

V-530-EXIC:  II 3 G Ex ic IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

**Liste des modèles** (liste de tous les modèles/versions de produits auxquels cette déclaration s'applique)

Modèle	Description
V-430-S	Multicriteria Detector with Sounder
V-530-S	Multicriteria Detector SIL2 with Sounder
V-430-VADW	Multicriteria Detector with White Beacon
V-530-VADW	Multicriteria Detector SIL2 with White Beacon
V-430-S-VADW	Multicriteria Detector with Sounder and White Beacon
V-530-S-VADW	Multicriteria SIL2 Detector with Sounder and White Beacon
V-430-SP	Multicriteria Detector with Speech
V-530-SP	Multicriteria Detector SIL2 with Speech
V-430-SP-VADW	Multicriteria Detector with Speech and White Beacon
V-530-SP-VADW	Multicriteria Detector SIL2 with Speech and White Beacon
V-430-SP-VADR	Multicriteria Detector with Speech and Red Beacon
V-530-SP-VADR	Multicriteria Detector SIL2 with Speech and Red Beacon
V-430-S-VADR	Multicriteria Detector with Sounder and Red Beacon
V-530-S-VADR	Multicriteria Detector SIL2 with Sounder and Red Beacon
V-430-VADR	Multicriteria Detector with Red Beacon
V-530-VADR	Multicriteria Detector SIL2 with Red Beacon
V-430	Multicriteria Detector
V-530	Multicriteria Detector SIL2
V-530-EXIA	Multicriteria Detector with SIL2 Ex ia
V-530-EXIC	Multicriteria Detector with SIL2 Ex ic
<p>Full model codes are defined by the formats V-430-xxxx-yy/ww/zz and V-530-xxxx-yy/ww/zz where:</p> <p>xxxx = Model as listed in the table above:            S, VADW, VADR, S-VADR, SP-VADW, SP-VADR, EXIA, EXIC</p> <p>yy = Color of housing:            Blank = White, BK = Black, CC = Customized Color</p> <p>ww = Enabled options:            Blank = None, CD = Cover Detection &amp; Self Verify, HS = Extra High Sensitivity*, DS = Data Subscription, CFxxx = Custom Features (C = A to Z, F = A to Z, xxx = 000 to 999)</p> <p>* Note that when the HS = Extra High Sensitivity setting is used, the product is not compliant with EN 54-7:2018.</p>	

Signature du représentant/fabricant :




Tomasz Dowgiałło, Chargé de la conformité  
 Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim, Norway

HR



# IZJAVA O SUKLADNOSTI PROIZVOĐAČA

ZA



**Identifikacija proizvoda:**


Model/tip: Pogledajte popis modela Početna godina postavljanja CE oznake: 2020  
 Kategorija (opis): Fire detection and fire alarm systems  
 Marka: Autronica

**Proizvođač:** Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim  
 Norway

**Predstavnik EU:** --

Odnosi se na	Uzorak proizvoda testirao je	Izvešće o ispitivanju	Primijenjeni standardi
<b>EMC</b>	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN 61000-6-3:2007+A1:2011+AC:2012 EN 50130-4:2011
<b>CPR</b>	Intertek Deatschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen, Germany	Certificate: 0905-CPR-00840	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010
<b>MED</b>	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: MEDB00006DJ MEDB0000646	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010 IEC 60092-504:2016 IEC 60533:2015
<b>ATEX</b>	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: DNV 21ATEX14779X (V-530-EXIA) DNV 22ATEX13772X (V-530-EXIC)	EN IEC 60079-0:2018 EN 60079-11:2012
<b>RoHS</b>	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN IEC 63000:2018

**Ograničenja stavljanja u uporabu / zahtjevi za odobrenje uporabe**

Nije primjenjivo  Nema ograničenja  

**Sredstva sukladnosti**

Izjavljujemo na vlastitu odgovornost da je ovaj proizvod u skladu s direktivama: 93/68/EEZ (označavanje), 2014/30/EU (EMC), 305/2011 (CPR), 2014/90/EU (MED), 2014/34/EU (ATEX), i 2011/65/EU (Direktiva za ograničavanje upotrebe određenih opasnih supstanci, RoHS), koja je izmijenjena direktivama 2015/863 i 2017/2102, te je u skladu s osnovnim zahtjevima i svim ostalim relevantnim odredbama ovih direktiva na temelju rezultata ispitivanja koristeći usklađene standarde, a u skladu s navedenim direktivama.

**ATEX:**

V-530-EXIA:  II 1 G Ex ia IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

Potpis predstavnika / proizvođača:



Tomasz Dowgiałło, voditelj Odjela za usklađenost  
 Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim, Norway

V-530-EXIC:



II 3 G Ex ic IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

**Popis modela** (popis svih inačica ili modela proizvoda za koje vrijedi ova izjava)

Model	Opis
V-430-S	Multicriteria Detector with Sounder
V-530-S	Multicriteria Detector SIL2 with Sounder
V-430-VADW	Multicriteria Detector with White Beacon
V-530-VADW	Multicriteria Detector SIL2 with White Beacon
V-430-S-VADW	Multicriteria Detector with Sounder and White Beacon
V-530-S-VADW	Multicriteria SIL2 Detector with Sounder and White Beacon
V-430-SP	Multicriteria Detector with Speech
V-530-SP	Multicriteria Detector SIL2 with Speech
V-430-SP-VADW	Multicriteria Detector with Speech and White Beacon
V-530-SP-VADW	Multicriteria Detector SIL2 with Speech and White Beacon
V-430-SP-VADR	Multicriteria Detector with Speech and Red Beacon
V-530-SP-VADR	Multicriteria Detector SIL2 with Speech and Red Beacon
V-430-S-VADR	Multicriteria Detector with Sounder and Red Beacon
V-530-S-VADR	Multicriteria Detector SIL2 with Sounder and Red Beacon
V-430-VADR	Multicriteria Detector with Red Beacon
V-530-VADR	Multicriteria Detector SIL2 with Red Beacon
V-430	Multicriteria Detector
V-530	Multicriteria Detector SIL2
V-530-EXIA	Multicriteria Detector with SIL2 Ex ia
V-530-EXIC	Multicriteria Detector with SIL2 Ex ic
<p>Full model codes are defined by the formats V-430-xxxxx-yy/ww/zz and V-530-xxxxx-yy/ww/zz where:</p> <p>xxxxx = Model as listed in the table above:            S, VADW, VADR, S-VADR, SP-VADW, SP-VADR, EXIA, EXIC</p> <p>yy = Color of housing:            Blank = White, BK = Black, CC = Customized Color</p> <p>ww = Enabled options:            Blank = None, CD = Cover Detection &amp; Self Verify, HS = Extra High Sensitivity*, DS = Data Subscription, CFxxx = Custom Features (C = A to Z, F = A to Z, xxx = 000 to 999)</p> <p>* Note that when the HS = Extra High Sensitivity setting is used, the product is not compliant with EN 54-7:2018.</p>	

Potpis predstavnika / proizvođača:




Tomasz Dowgiatto, voditelj Odjela za usklađenost  
 Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim, Norway

HU



# A GYÁRTÓ MEGFELELŐSÉGI NYILATKOZATA



AZ ALÁBBIakra VONATKOZÓAN

**Termékazonosító:**

Modell/típus: Lásd: modellek felsorolása A CE-jelölés elhelyezésének első éve: 2020  
Kategória (leírás): Fire detection and fire alarm systems  
Márka: Autronica

**Gyártó:** Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim  
Norway

**EU-képviselő:** --

Irányelv	Termékminta tesztelését végezte	Vizsgálati jelentés hivatkozása	Alkalmazott szabványok
EMC	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN 61000-6-3:2007+A1:2011+AC:2012 EN 50130-4:2011
CPR	Intertek Deatschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen, Germany	Certificate: 0905-CPR-00840	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010
MED	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: MEDB00006DJ MEDB0000646	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010 IEC 60092-504:2016 IEC 60533:2015
ATEX	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: DNV 21ATEX14779X (V-530-EXIA) DNV 22ATEX13772X (V-530-EXIC)	EN IEC 60079-0:2018 EN 60079-11:2012
RoHS	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN IEC 63000:2018

**Üzembe helyezési korlátozások/használatbavételi engedélyre vonatkozó követelmények**

Nem alkalmazható  Egyik sem

**A megfelelés módjai**

Kizárólagos felelősségünk tudatában kijelentjük, hogy a termék megfelel az alábbi irányelveknek: 93/68/EGK (jelölés), 2014/30/EU (EMC), 305/2011 (CPR); 2014/90/EU (MED), 2014/34/EU (ATEX), továbbá a 2015/863 és 2017/2102 rendelet által módosított 2011/65/EU (RoHS), és megfelel az alapvető követelményeknek és az irányelvek minden más vonatkozó rendelkezésének az említett irányelvekkel összhangban lévő harmonizált szabványok felhasználásával végzett vizsgálatok eredményei alapján.

A képviselő/gyártó aláírása:

Tomasz Dowgiałło, megfeleléségi vezető  
Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim, Norway

**ATEX:**

V-530-EXIA:  II 1 G Ex ia IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

V-530-EXIC:  II 3 G Ex ic IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

**Modellek felsorolása** (Azon termékváltozatok vagy modellek listája, amelyekre ez a nyilatkozat érvényes)

Modell	Leírás
V-430-S	Multicriteria Detector with Sounder
V-530-S	Multicriteria Detector SIL2 with Sounder
V-430-VADW	Multicriteria Detector with White Beacon
V-530-VADW	Multicriteria Detector SIL2 with White Beacon
V-430-S-VADW	Multicriteria Detector with Sounder and White Beacon
V-530-S-VADW	Multicriteria SIL2 Detector with Sounder and White Beacon
V-430-SP	Multicriteria Detector with Speech
V-530-SP	Multicriteria Detector SIL2 with Speech
V-430-SP-VADW	Multicriteria Detector with Speech and White Beacon
V-530-SP-VADW	Multicriteria Detector SIL2 with Speech and White Beacon
V-430-SP-VADR	Multicriteria Detector with Speech and Red Beacon
V-530-SP-VADR	Multicriteria Detector SIL2 with Speech and Red Beacon
V-430-S-VADR	Multicriteria Detector with Sounder and Red Beacon
V-530-S-VADR	Multicriteria Detector SIL2 with Sounder and Red Beacon
V-430-VADR	Multicriteria Detector with Red Beacon
V-530-VADR	Multicriteria Detector SIL2 with Red Beacon
V-430	Multicriteria Detector
V-530	Multicriteria Detector SIL2
V-530-EXIA	Multicriteria Detector with SIL2 Ex ia
V-530-EXIC	Multicriteria Detector with SIL2 Ex ic
<p>Full model codes are defined by the formats V-430-xxxx-yy/ww/zz and V-530-xxxx-yy/ww/zz where:</p> <p>xxxx = Model as listed in the table above:  S, VADW, VADR, S-VADR, SP-VADW, SP-VADR, EXIA, EXIC</p> <p>yy = Color of housing:  Blank = White, BK = Black, CC = Customized Color</p> <p>ww = Enabled options:  Blank = None, CD = Cover Detection &amp; Self Verify, HS = Extra High Sensitivity*, DS = Data Subscription, CFxxx = Custom Features (C = A to Z, F = A to Z, xxx = 000 to 999)</p> <p>* Note that when the HS = Extra High Sensitivity setting is used, the product is not compliant with EN 54-7:2018.</p>	

A képviselő/gyártó aláírása:




Tomasz Dowgiałło, megfelelőségi vezető  
Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim, Norway

IT



# DICHIARAZIONE DI CONFORMITÀ DEL PRODUTTORE



PER

**Identificazione del prodotto:**

Modello/tipo: Fare riferimento all'elenco dei modelli Anno iniziale di applicazione del marchio CE: 2020

Categoria (descrizione): Fire detection and fire alarm systems

Marca: Autronica

**Fabbricante:** Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim  
Norway

**Rappresentante UE:** --

Relativo a	Un campione del prodotto è stato testato da	Riferimento report di test	Standard applicati
EMC	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN 61000-6-3:2007+A1:2011+AC:2012 EN 50130-4:2011
CPR	Intertek Deatschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen, Germany	Certificate: 0905-CPR-00840	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010
MED	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: MEDB00006DJ MEDB0000646	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010 IEC 60092-504:2016 IEC 60533:2015
ATEX	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: DNV 21ATEX14779X (V-530-EXIA) DNV 22ATEX13772X (V-530-EXIC)	EN IEC 60079-0:2018 EN 60079-11:2012
RoHS	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN IEC 63000:2018

**Restrizioni sulla messa in servizio/requisiti per l'autorizzazione all'uso**

Non applicabile

Nessuna.



**Conformità**

Il produttore dichiara, sotto la propria responsabilità, che questo prodotto è conforme alle Direttive: 93/68/EEC (marchio), 2014/30/EU (EMC), 305/2011 (CPR), 2014/90/EU (MED), e 2011/65/EU (RoHS), 2014/34/EU (ATEX), modificata da 2015/863 e 2017/2102 ed è conforme ai requisiti essenziali e a tutte le altre relative disposizioni delle Direttive in base ai risultati del test che utilizzano standard armonizzati in conformità con le Direttive citate.

Firma del rappresentante/produttore:



Tomasz Dowgiałło, Compliance Leader  
Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim, Norway

**ATEX:**

V-530-EXIA:  II 1 G Ex ia IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

V-530-EXIC:  II 3 G Ex ic IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

**Elenco di modelli** (elenco di tutte le varianti di prodotto o modelli per cui questa dichiarazione è valida)

Modello	Descrizione
V-430-S	Multicriteria Detector with Sounder
V-530-S	Multicriteria Detector SIL2 with Sounder
V-430-VADW	Multicriteria Detector with White Beacon
V-530-VADW	Multicriteria Detector SIL2 with White Beacon
V-430-S-VADW	Multicriteria Detector with Sounder and White Beacon
V-530-S-VADW	Multicriteria SIL2 Detector with Sounder and White Beacon
V-430-SP	Multicriteria Detector with Speech
V-530-SP	Multicriteria Detector SIL2 with Speech
V-430-SP-VADW	Multicriteria Detector with Speech and White Beacon
V-530-SP-VADW	Multicriteria Detector SIL2 with Speech and White Beacon
V-430-SP-VADR	Multicriteria Detector with Speech and Red Beacon
V-530-SP-VADR	Multicriteria Detector SIL2 with Speech and Red Beacon
V-430-S-VADR	Multicriteria Detector with Sounder and Red Beacon
V-530-S-VADR	Multicriteria Detector SIL2 with Sounder and Red Beacon
V-430-VADR	Multicriteria Detector with Red Beacon
V-530-VADR	Multicriteria Detector SIL2 with Red Beacon
V-430	Multicriteria Detector
V-530	Multicriteria Detector SIL2
V-530-EXIA	Multicriteria Detector with SIL2 Ex ia
V-530-EXIC	Multicriteria Detector with SIL2 Ex ic
<p>Full model codes are defined by the formats V-430-xxxx-yy/ww/zz and V-530-xxxx-yy/ww/zz where:</p> <p>xxxx = Model as listed in the table above:  S, VADW, VADR, S-VADR, SP-VADW, SP-VADR, EXIA, EXIC</p> <p>yy = Color of housing:  Blank = White, BK = Black, CC = Customized Color</p> <p>ww = Enabled options:  Blank = None, CD = Cover Detection &amp; Self Verify, HS = Extra High Sensitivity*, DS = Data Subscription, CFxxx = Custom Features (C = A to Z, F = A to Z, xxx = 000 to 999)</p> <p>* Note that when the HS = Extra High Sensitivity setting is used, the product is not compliant with EN 54-7:2018.</p>	

Firma del rappresentante/produttore:



Tomasz Dowgiałło, Compliance Leader  
Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim, Norway




LT



## GAMINTOJO ATITIKTIES DEKLARACIJA

DĒL



## Gaminio identifikavimas:

Modelis / tipas: Žr. modelių sąrašą

Pirmi metai ženklinant CE ženklui: 2020

Kategorija (apibūdinimas): Fire detection and fire alarm systems

Prekės ženklas: Autronica

Gamintojas: Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim  
Norway

ES atstovas: --

Dėl	Gaminio pavyzdį išbandė	Bandyimo ataskaitos nuoroda	Taikomi standartai
EMC	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN 61000-6-3:2007+A1:2011+AC:2012 EN 50130-4:2011
CPR	Intertek Deatschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen, Germany	Certificate: 0905-CPR-00840	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010
MED	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: MEDB00006DJ MEDB0000646	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010 IEC 60092-504:2016 IEC 60533:2015
ATEX	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: DNV 21ATEX14779X (V-530-EXIA) DNV 22ATEX13772X (V-530-EXIC)	EN IEC 60079-0:2018 EN 60079-11:2012
RoHS	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN IEC 63000:2018

## Eksploatacijos pradžios apribojimai / naudojimo leidimo reikalavimai

 Netaikoma Nėra

## Atitikties priemonės

Mes tik savo atsakomybe pareiškiame, kad šis gaminys atitinka direktyvas: 93/68/EEB (ženklinimas), 2014/30/ES (EMC), 305/2011 (CPR), 2014/90/EU (MED), 2014/34/EU (ATEX), ir 2011/65/ES (RoHS) su pakeitimais, padarytais 2015/863 ir 2017/2102, ir atitinka esminius reikalavimus ir visas kitas atitinkamas direktyvų nuostatas, pagrįstas bandymų rezultatais, naudojant suderintus standartus pagal minėtas direktyvas.

## ATEX:

V-530-EXIA:



II 1 G Ex ia IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

Atstovo / gamintojo parašas:

Tomasz Dowgiałło, atitikties vadovas  
Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim, Norway

Vieta: Gdanskas, Lenkija

Data: 30 rugsėjo 2022

25 p. iš 40

Dok. Nr.: 60. 1005405

V-530-EXIC:



II 3 G Ex ic IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

**Modelių sąrašas** (visų gaminių variantų ar modelių, kuriems galioja ši deklaracija, sąrašas)

Modelis	Apibūdinimas
V-430-S	Multicriteria Detector with Sounder
V-530-S	Multicriteria Detector SIL2 with Sounder
V-430-VADW	Multicriteria Detector with White Beacon
V-530-VADW	Multicriteria Detector SIL2 with White Beacon
V-430-S-VADW	Multicriteria Detector with Sounder and White Beacon
V-530-S-VADW	Multicriteria SIL2 Detector with Sounder and White Beacon
V-430-SP	Multicriteria Detector with Speech
V-530-SP	Multicriteria Detector SIL2 with Speech
V-430-SP-VADW	Multicriteria Detector with Speech and White Beacon
V-530-SP-VADW	Multicriteria Detector SIL2 with Speech and White Beacon
V-430-SP-VADR	Multicriteria Detector with Speech and Red Beacon
V-530-SP-VADR	Multicriteria Detector SIL2 with Speech and Red Beacon
V-430-S-VADR	Multicriteria Detector with Sounder and Red Beacon
V-530-S-VADR	Multicriteria Detector SIL2 with Sounder and Red Beacon
V-430-VADR	Multicriteria Detector with Red Beacon
V-530-VADR	Multicriteria Detector SIL2 with Red Beacon
V-430	Multicriteria Detector
V-530	Multicriteria Detector SIL2
V-530-EXIA	Multicriteria Detector with SIL2 Ex ia
V-530-EXIC	Multicriteria Detector with SIL2 Ex ic
<p>Full model codes are defined by the formats V-430-xxxx-yy/ww/zz and V-530-xxxx-yy/ww/zz where:</p> <p>xxxx = Model as listed in the table above: S, VADW, VADR, S-VADR, SP-VADW, SP-VADR, EXIA, EXIC</p> <p>yy = Color of housing: Blank = White, BK = Black, CC = Customized Color</p> <p>ww = Enabled options: Blank = None, CD = Cover Detection &amp; Self Verify, HS = Extra High Sensitivity*, DS = Data Subscription, CFxxx = Custom Features (C = A to Z, F = A to Z, xxx = 000 to 999)</p> <p>* Note that when the HS = Extra High Sensitivity setting is used, the product is not compliant with EN 54-7:2018.</p>	

Atstovo / gamintojo parašas:




Tomasz Dowgiało, atitikties vadovas  
Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim, Norway

NL



# CONFORMITEITSVERKLARING VAN DE FABRIKANT



VOOR

**Productidentificatie:**

Model/type: Raadpleeg de modellijst Eerste jaar met CE-markering: 2020  
 Categorie (beschrijving): Fire detection and fire alarm systems  
 Merk: Autronica

**Fabrikant:** Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim  
 Norway

**EU-vertegenwoordiger:** --

Met betrekking tot	Een sample van het product is getest door	Referentie testmelding	Toegepaste normen
EMC	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN 61000-6-3:2007+A1:2011+AC:2012 EN 50130-4:2011
CPR	Intertek Deatschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen, Germany	Certificate: 0905-CPR-00840	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010
MED	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: MEDB00006DJ MEDB0000646	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010 IEC 60092-504:2016 IEC 60533:2015
ATEX	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: DNV 21ATEX14779X (V-530-EXIA) DNV 22ATEX13772X (V-530-EXIC)	EN IEC 60079-0:2018 EN 60079-11:2012
RoHS	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN IEC 63000:2018

**Beperkingen op het in gebruik nemen/vereisten voor autorisatie van gebruik**

Niet van toepassing  Geen  

**Conformiteitsmiddelen**

Wij verklaren onder onze eigen verantwoordelijkheid dat dit product in overeenstemming is met de richtlijnen: 93/68/EEG (markering), 2014/30/EU (EMC), 305/2011 (CPR), 2014/90/EU (MED), 2014/34/EU (ATEX), en 2011/65/EU (RoHS), zoals gewijzigd door 2015/863 en 2017/2102, en dat het product voldoet aan de essentiële vereisten en alle andere relevante bepalingen van de richtlijnen op basis van testresultaten aan de hand van geharmoniseerde normen, conform de genoemde richtlijnen.

Handtekening vertegenwoordiger/fabrikant:



Tomasz Dowgiałto, Compliance Leader  
 Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim, Norway

Plaats: Gdańsk, Polen

Datum: 30 september 2022

Pagina 27 van 40

Doc. Nr.: 60. 1005405

**ATEX:**

V-530-EXIA:  II 1 G Ex ia IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

V-530-EXIC:  II 3 G Ex ic IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

**Modellijst** (lijst van alle productvarianten of modellen waarvoor deze verklaring geldig is)

Model	Beschrijving
V-430-S	Multicriteria Detector with Sounder
V-530-S	Multicriteria Detector SIL2 with Sounder
V-430-VADW	Multicriteria Detector with White Beacon
V-530-VADW	Multicriteria Detector SIL2 with White Beacon
V-430-S-VADW	Multicriteria Detector with Sounder and White Beacon
V-530-S-VADW	Multicriteria SIL2 Detector with Sounder and White Beacon
V-430-SP	Multicriteria Detector with Speech
V-530-SP	Multicriteria Detector SIL2 with Speech
V-430-SP-VADW	Multicriteria Detector with Speech and White Beacon
V-530-SP-VADW	Multicriteria Detector SIL2 with Speech and White Beacon
V-430-SP-VADR	Multicriteria Detector with Speech and Red Beacon
V-530-SP-VADR	Multicriteria Detector SIL2 with Speech and Red Beacon
V-430-S-VADR	Multicriteria Detector with Sounder and Red Beacon
V-530-S-VADR	Multicriteria Detector SIL2 with Sounder and Red Beacon
V-430-VADR	Multicriteria Detector with Red Beacon
V-530-VADR	Multicriteria Detector SIL2 with Red Beacon
V-430	Multicriteria Detector
V-530	Multicriteria Detector SIL2
V-530-EXIA	Multicriteria Detector with SIL2 Ex ia
V-530-EXIC	Multicriteria Detector with SIL2 Ex ic
<p>Full model codes are defined by the formats V-430-xxxx-yy/ww/zz and V-530-xxxx-yy/ww/zz where:</p> <p>xxxx = Model as listed in the table above:            S, VADW, VADR, S-VADR, SP-VADW, SP-VADR, EXIA, EXIC</p> <p>yy = Color of housing:            Blank = White, BK = Black, CC = Customized Color</p> <p>ww = Enabled options:            Blank = None, CD = Cover Detection &amp; Self Verify, HS = Extra High Sensitivity*, DS = Data Subscription, CFxxx = Custom Features (C = A to Z, F = A to Z, xxx = 000 to 999)</p> <p>* Note that when the HS = Extra High Sensitivity setting is used, the product is not compliant with EN 54-7:2018.</p>	

Handtekening vertegenwoordiger/fabrikant:




Tomasz Dowgiałło, Compliance Leader  
 Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim, Norway

NO



# PRODUSENTENS SAMSVARERKLÆRING



FOR

**Produktidentifikasjon:**


Modell/type: Referer til modelloppføring Første år påført CE-merke: 2020  
 Kategori (beskrivelse): Fire detection and fire alarm systems  
 Merke: Autronica

**Produsent:** Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim  
 Norway

**EU-representant:** --

Angjeldende	En prøve av produktet har blitt testet av	Testrapportreferanse	Anvendte standarder
EMC	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN 61000-6-3:2007+A1:2011+AC:2012 EN 50130-4:2011
CPR	Intertek Deatschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen, Germany	Certificate: 0905-CPR-00840	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010
MED	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: MEDB00006DJ MEDB0000646	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010 IEC 60092-504:2016 IEC 60533:2015
ATEX	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: DNV 21ATEX14779X (V-530-EXIA) DNV 22ATEX13772X (V-530-EXIC)	EN IEC 60079-0:2018 EN 60079-11:2012
RoHS	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN IEC 63000:2018

**Begrensninger på å sette i drift/krav til autorisering av bruk**

Ikke aktuelt  Ingen  

**Samsvarsmetode**

Vi erklærer etter eget ansvar at dette produktet er i samsvar med direktivene: 93/68/EØS (merking), 2014/30/EU (EMC), 305/2011 (CPR), 2014/90/EU (MED), 2014/34/EU (ATEX), og 2011/65/EU (RoHS), endret av 2015/863 og 2017/2102, og samsvarer med de vesentlige kravene og alle relevante bestemmelser av direktivene basert på testresultater ved hjelp av harmoniserte standarder i samsvar med de nevnte direktivene.

**ATEX:**

V-530-EXIA:  II 1 G Ex ia IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

Signatur fra representant/produsent:



Tomasz Dowgiałło, samsvarsleder  
 Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim, Norway

Sted: Gdańsk, Polen

Dato: 30 september 2022

Side 29 av 40

dok. nr.: 60. 1005405

V-530-EXIC:



II 3 G Ex ic IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

**Modelloppføring** (liste over alle produktvarianter eller modeller som erklæringen er gyldig for)

Modell	Beskrivelse
V-430-S	Multicriteria Detector with Sounder
V-530-S	Multicriteria Detector SIL2 with Sounder
V-430-VADW	Multicriteria Detector with White Beacon
V-530-VADW	Multicriteria Detector SIL2 with White Beacon
V-430-S-VADW	Multicriteria Detector with Sounder and White Beacon
V-530-S-VADW	Multicriteria SIL2 Detector with Sounder and White Beacon
V-430-SP	Multicriteria Detector with Speech
V-530-SP	Multicriteria Detector SIL2 with Speech
V-430-SP-VADW	Multicriteria Detector with Speech and White Beacon
V-530-SP-VADW	Multicriteria Detector SIL2 with Speech and White Beacon
V-430-SP-VADR	Multicriteria Detector with Speech and Red Beacon
V-530-SP-VADR	Multicriteria Detector SIL2 with Speech and Red Beacon
V-430-S-VADR	Multicriteria Detector with Sounder and Red Beacon
V-530-S-VADR	Multicriteria Detector SIL2 with Sounder and Red Beacon
V-430-VADR	Multicriteria Detector with Red Beacon
V-530-VADR	Multicriteria Detector SIL2 with Red Beacon
V-430	Multicriteria Detector
V-530	Multicriteria Detector SIL2
V-530-EXIA	Multicriteria Detector with SIL2 Ex ia
V-530-EXIC	Multicriteria Detector with SIL2 Ex ic
<p>Full model codes are defined by the formats V-430-xxxxx-yy/ww/zz and V-530-xxxxx-yy/ww/zz where:</p> <p>xxxxx = Model as listed in the table above: S, VADW, VADR, S-VADR, SP-VADW, SP-VADR, EXIA, EXIC</p> <p>yy = Color of housing: Blank = White, BK = Black, CC = Customized Color</p> <p>ww = Enabled options: Blank = None, CD = Cover Detection &amp; Self Verify, HS = Extra High Sensitivity*, DS = Data Subscription, CFxxx = Custom Features (C = A to Z, F = A to Z, xxx = 000 to 999)</p> <p>* Note that when the HS = Extra High Sensitivity setting is used, the product is not compliant with EN 54-7:2018.</p>	

Signatur fra representant/produsent:



Tomasz Dowgiało, samsvarsleder  
Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim, Norway

Sted: Gdańsk, Polen

Dato: 30 september 2022


Side 30 av 40

dok. nr.: 60. 1005405

PL



# DEKLARACJA ZGODNOŚCI PRODUCENTA



DOTYCZY

**Identyfikacja produktu:**


Model/typ: Patrz lista modeli Rok początkowy umieszczenia znaku CE: 2020  
 Kategoria (opis): Fire detection and fire alarm systems  
 Marka: Autronica

**Producent:** Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim  
 Norway

**Reprezentacja EU:** --

Odniesienie do	Próbka została przetestowana przez	Raport z testów	Zastosowane normy
<b>EMC</b>	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN 61000-6-3:2007+A1:2011+AC:2012 EN 50130-4:2011
<b>CPR</b>	Intertek Deatschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen, Germany	Certificate: 0905-CPR-00840	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010
<b>MED</b>	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: MEDB00006DJ MEDB0000646	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010 IEC 60092-504:2016 IEC 60533:2015
<b>ATEX</b>	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: DNV 21ATEX14779X (V-530-EXIA) DNV 22ATEX13772X (V-530-EXIC)	EN IEC 60079-0:2018 EN 60079-11:2012
<b>RoHS</b>	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN IEC 63000:2018

**Ograniczenia dotyczące dopuszczenia do użytku/wymagania dotyczące dopuszczenia do użytku**

Nie dotyczy  Brak  

**Środki zgodności**

Deklarujemy na naszą wyłączną odpowiedzialność, że niniejszy produkt jest zgodny z dyrektywami: 93/68/EEC (Oznaczenia), 2014/30/EU (EMC), 305/2011 (CPR), 2014/90/EU (MED), 2014/34/EU (ATEX), oraz 2011/65/EU (RoHS - Ograniczenia dotyczące substancji niebezpiecznych), z poprawkami w 2015/863 i 2017/2102 oraz pozostaje w zgodzie z zasadniczymi wymogami i wszystkimi innymi stosownymi przepisami Dyrektyw w oparciu o wyniki badań przy użyciu zharmonizowanych norm zgodnie z wymienionymi dyrektywami..

Podpis przedstawiciela/producenta:



Tomasz Dowgiałło, Lider ds. zgodności z normami  
 Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim, Norway

**ATEX:**

V-530-EXIA:  II 1 G Ex ia IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

V-530-EXIC:  II 3 G Ex ic IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

**Lista modeli** (Wykaz wszystkich wariantów lub modeli produktu, dla których obowiązuje niniejsza deklaracja)

Model	Opis
V-430-S	Multicriteria Detector with Sounder
V-530-S	Multicriteria Detector SIL2 with Sounder
V-430-VADW	Multicriteria Detector with White Beacon
V-530-VADW	Multicriteria Detector SIL2 with White Beacon
V-430-S-VADW	Multicriteria Detector with Sounder and White Beacon
V-530-S-VADW	Multicriteria SIL2 Detector with Sounder and White Beacon
V-430-SP	Multicriteria Detector with Speech
V-530-SP	Multicriteria Detector SIL2 with Speech
V-430-SP-VADW	Multicriteria Detector with Speech and White Beacon
V-530-SP-VADW	Multicriteria Detector SIL2 with Speech and White Beacon
V-430-SP-VADR	Multicriteria Detector with Speech and Red Beacon
V-530-SP-VADR	Multicriteria Detector SIL2 with Speech and Red Beacon
V-430-S-VADR	Multicriteria Detector with Sounder and Red Beacon
V-530-S-VADR	Multicriteria Detector SIL2 with Sounder and Red Beacon
V-430-VADR	Multicriteria Detector with Red Beacon
V-530-VADR	Multicriteria Detector SIL2 with Red Beacon
V-430	Multicriteria Detector
V-530	Multicriteria Detector SIL2
V-530-EXIA	Multicriteria Detector with SIL2 Ex ia
V-530-EXIC	Multicriteria Detector with SIL2 Ex ic
Full model codes are defined by the formats V-430-xxxx-yy/ww/zz and V-530-xxxx-yy/ww/zz where: xxxx = Model as listed in the table above: S, VADW, VADR, S-VADR, SP-VADW, SP-VADR, EXIA, EXIC yy = Color of housing: Blank = White, BK = Black, CC = Customized Color ww = Enabled options: Blank = None, CD = Cover Detection & Self Verify, HS = Extra High Sensitivity*, DS = Data Subscription, CFxxx = Custom Features (C = A to Z, F = A to Z, xxx = 000 to 999) * Note that when the HS = Extra High Sensitivity setting is used, the product is not compliant with EN 54-7:2018.	

Podpis przedstawiciela/producenta:




Tomasz Dowgiałło, Lider ds. zgodności z normami  
Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim, Norway



PT



# DECLARAÇÃO DE CONFORMIDADE DO FABRICANTE



PARA

**Identificação do produto:**

Modelo/tipo: Consulte a listagem de modelos Ano inicial de afixação da marcação CE: 2020  
Categoria (descrição): Fire detection and fire alarm systems  
Marca: Autronica

**Fabricante:** Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim  
Norway

**Representante na UE:** --

Relativamente a	Foi testada uma amostra do produto por	Referência do relatório de teste	Normas aplicadas
EMC	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN 61000-6-3:2007+A1:2011+AC:2012 EN 50130-4:2011
CPR	Intertek Deatschland GmbH, Stangenstraße 1, 70771 Leinfeldern-Echterdingen, Germany	Certificate: 0905-CPR-00840	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010
MED	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: MEDB00006DJ MEDB0000646	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010 IEC 60092-504:2016 IEC 60533:2015
ATEX	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: DNV 21ATEX14779X (V-530-EXIA) DNV 22ATEX13772X (V-530-EXIC)	EN IEC 60079-0:2018 EN 60079-11:2012
RoHS	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN IEC 63000:2018

**Restrições de colocação em serviço/requisitos para autorização de utilização** Não aplicável Nenhum**Meios de conformidade**

Declaramos, sob nossa única responsabilidade, que este produto está em conformidade com as Diretivas: 93/68/CEE (Marcação), 2014/30/EU (EMC), 305/2011 (CPR), 2014/90/EU (MED), 2014/34/EU (ATEX), e 2011/65/EU (RoHS), emendada pela 2015/863 e 2017/2102, e está em conformidade com os requisitos essenciais e todas as outras disposições relevantes das Diretivas baseadas em resultados de testes utilizando as normas harmonizadas de acordo com as Diretivas mencionadas.

Assinatura do representante/fabricante:

Tomasz Dowgiałło, Compliance Leader  
Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim, Norway

**ATEX:**

V-530-EXIA:  II 1 G Ex ia IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

V-530-EXIC:  II 3 G Ex ic IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

**Listagem de modelos** (Lista de todas as variantes ou modelos de produtos para os quais esta variante é válida)

Modelo	Descrição
V-430-S	Multicriteria Detector with Sounder
V-530-S	Multicriteria Detector SIL2 with Sounder
V-430-VADW	Multicriteria Detector with White Beacon
V-530-VADW	Multicriteria Detector SIL2 with White Beacon
V-430-S-VADW	Multicriteria Detector with Sounder and White Beacon
V-530-S-VADW	Multicriteria SIL2 Detector with Sounder and White Beacon
V-430-SP	Multicriteria Detector with Speech
V-530-SP	Multicriteria Detector SIL2 with Speech
V-430-SP-VADW	Multicriteria Detector with Speech and White Beacon
V-530-SP-VADW	Multicriteria Detector SIL2 with Speech and White Beacon
V-430-SP-VADR	Multicriteria Detector with Speech and Red Beacon
V-530-SP-VADR	Multicriteria Detector SIL2 with Speech and Red Beacon
V-430-S-VADR	Multicriteria Detector with Sounder and Red Beacon
V-530-S-VADR	Multicriteria Detector SIL2 with Sounder and Red Beacon
V-430-VADR	Multicriteria Detector with Red Beacon
V-530-VADR	Multicriteria Detector SIL2 with Red Beacon
V-430	Multicriteria Detector
V-530	Multicriteria Detector SIL2
V-530-EXIA	Multicriteria Detector with SIL2 Ex ia
V-530-EXIC	Multicriteria Detector with SIL2 Ex ic
<p>Full model codes are defined by the formats V-430-xxxx-yy/ww/zz and V-530-xxxx-yy/ww/zz where:</p> <p>xxxx = Model as listed in the table above:            S, VADW, VADR, S-VADR, SP-VADW, SP-VADR, EXIA, EXIC</p> <p>yy = Color of housing:            Blank = White, BK = Black, CC = Customized Color</p> <p>ww = Enabled options:            Blank = None, CD = Cover Detection &amp; Self Verify, HS = Extra High Sensitivity*, DS = Data Subscription, CFxxx = Custom Features (C = A to Z, F = A to Z, xxx = 000 to 999)</p> <p>* Note that when the HS = Extra High Sensitivity setting is used, the product is not compliant with EN 54-7:2018.</p>	

Assinatura do representante/fabricante:




Tomasz Dowgiałło, Compliance Leader  
 Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim, Norway

SK



# VYHLÁSENIE VÝROBCU O ZHODE

PRE



**Identifikácia výrobku:**


Model/typ: Pozrite si zoznam modelov Umiestnenie označenia CE od roku: 2020  
 Kategória (opis): Fire detection and fire alarm systems  
 Značka: Autronica

**Výrobca:** Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim  
 Norway

**Zástupca v EÚ:** --

Týka sa	Vzorku výrobku testovala spoločnosť	Odkaz na protokol o skúške	Použité normy
EMC	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN 61000-6-3:2007+A1:2011+AC:2012 EN 50130-4:2011
CPR	Intertek Deatschland GmbH, Stangenstraße 1, 70771 Leinfeld-Echterdingen, Germany	Certificate: 0905-CPR-00840	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010
MED	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: MEDB00006DJ MEDB0000646	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010 IEC 60092-504:2016 IEC 60533:2015
ATEX	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: DNV 21ATEX14779X (V-530-EXIA) DNV 22ATEX13772X (V-530-EXIC)	EN IEC 60079-0:2018 EN 60079-11:2012
RoHS	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN IEC 63000:2018

**Obmedzenia uvedenia do prevádzky/požiadavky na povolenie na používanie**

Nevzťahuje sa  Žiadne  

**Prostriedky preukázania zhody**

Vyhlasujeme na vlastnú zodpovednosť, že tento výrobok je v súlade s predpismi: smernica 93/68/EHS (značenie), 2014/30/EU (EMC), 305/2011 (CPR), 2014/90/EU (MED), 2014/34/EU (ATEX), a smernica 2011/65/EÚ (RoHS) v znení smerníc 2015/863 a 2017/2102 a je v súlade so základnými požiadavkami a všetkými ostatnými príslušnými ustanoveniami smerníc na základe výsledkov skúšok s použitím harmonizovaných noriem v súlade s uvedenými smernicami.

**ATEX:**

V-530-EXIA:  II 1 G Ex ia IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

Podpis zástupcu/výrobcu:



Tomasz Dowgiałło, vedúci oddelenia pre súlad s predpismi  
 Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim, Norway

V-530-EXIC:



II 3 G Ex ic IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

**Zoznam modelov** (zoznam všetkých variantov alebo modelov výrobku, pre ktoré platí toto vyhlásenie)

Model	Opis
V-430-S	Multicriteria Detector with Sounder
V-530-S	Multicriteria Detector SIL2 with Sounder
V-430-VADW	Multicriteria Detector with White Beacon
V-530-VADW	Multicriteria Detector SIL2 with White Beacon
V-430-S-VADW	Multicriteria Detector with Sounder and White Beacon
V-530-S-VADW	Multicriteria SIL2 Detector with Sounder and White Beacon
V-430-SP	Multicriteria Detector with Speech
V-530-SP	Multicriteria Detector SIL2 with Speech
V-430-SP-VADW	Multicriteria Detector with Speech and White Beacon
V-530-SP-VADW	Multicriteria Detector SIL2 with Speech and White Beacon
V-430-SP-VADR	Multicriteria Detector with Speech and Red Beacon
V-530-SP-VADR	Multicriteria Detector SIL2 with Speech and Red Beacon
V-430-S-VADR	Multicriteria Detector with Sounder and Red Beacon
V-530-S-VADR	Multicriteria Detector SIL2 with Sounder and Red Beacon
V-430-VADR	Multicriteria Detector with Red Beacon
V-530-VADR	Multicriteria Detector SIL2 with Red Beacon
V-430	Multicriteria Detector
V-530	Multicriteria Detector SIL2
V-530-EXIA	Multicriteria Detector with SIL2 Ex ia
V-530-EXIC	Multicriteria Detector with SIL2 Ex ic
<p>Full model codes are defined by the formats V-430-xxxx-yy/ww/zz and V-530-xxxx-yy/ww/zz where:</p> <p>xxxx = Model as listed in the table above:            S, VADW, VADR, S-VADR, SP-VADW, SP-VADR, EXIA, EXIC</p> <p>yy = Color of housing:            Blank = White, BK = Black, CC = Customized Color</p> <p>ww = Enabled options:            Blank = None, CD = Cover Detection &amp; Self Verify, HS = Extra High Sensitivity*, DS = Data Subscription, CFxxx = Custom Features (C = A to Z, F = A to Z, xxx = 000 to 999)</p> <p>* Note that when the HS = Extra High Sensitivity setting is used, the product is not compliant with EN 54-7:2018.</p>	

Podpis zástupcu/výrobcu:




Tomasz Dowgiałło, vedúci oddelenia pre súlad s predpismi  
 Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim, Norway

SL



# IZJAVA PROIZVAJALCA O SKLADNOSTI



ZA

**Identifikacija izdelka:**

Model/tip: Oglejte si seznam modelov Začetno leto namestitve oznake CE: 2020  
Kategorija (opis): Fire detection and fire alarm systems  
Blagovna znamka: Autronica

**Proizvajalec:** Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim  
Norway

**Predstavnik EU:** --

Zadeva	Vzorec izdelka je preveril/a	Sklic na poročilo o preskusu	Uporabljeni standardi
EMC	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN 61000-6-3:2007+A1:2011+AC:2012 EN 50130-4:2011
CPR	Intertek Deutschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen, Germany	Certificate: 0905-CPR-00840	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010
MED	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: MEDB00006DJ MEDB0000646	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010 IEC 60092-504:2016 IEC 60533:2015
ATEX	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: DNV 21ATEX14779X (V-530-EXIA) DNV 22ATEX13772X (V-530-EXIC)	EN IEC 60079-0:2018 EN 60079-11:2012
RoHS	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN IEC 63000:2018

**Omejitve pri začetku obratovanja/zahteve za odobritev uporabe** Ni uporabno Brez**Sredstva za skladnost**

Na lastno odgovornost izjavljamo, da je ta izdelek v skladu z direktivami: 93/68/EGS (označevanje), 2014/30/EU (EMC), 305/2011 (CPR), 2014/90/EU (MED), 2014/34/EU (ATEX), in 2011/65/EU (RoHS), spremenjeni z 2015/863 in 2017/2102, ter izpolnjuje bistvene zahteve in vse druge ustrezne določbe direktiv, ki temeljijo na rezultatih preskusov z uporabo usklajenih standardov v skladu z navedenimi direktivami.

Podpis zastopnika/proizvajalca:



Tomasz Dowgiałło, vodja Oddelka za skladnost  
Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim, Norway

**ATEX:**

V-530-EXIA:  II 1 G Ex ia IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

V-530-EXIC:  II 3 G Ex ic IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

**Seznam modelov** (seznam vseh različic ali modelov izdelkov, za katere velja ta izjava)

Model	Opis
V-430-S	Multicriteria Detector with Sounder
V-530-S	Multicriteria Detector SIL2 with Sounder
V-430-VADW	Multicriteria Detector with White Beacon
V-530-VADW	Multicriteria Detector SIL2 with White Beacon
V-430-S-VADW	Multicriteria Detector with Sounder and White Beacon
V-530-S-VADW	Multicriteria SIL2 Detector with Sounder and White Beacon
V-430-SP	Multicriteria Detector with Speech
V-530-SP	Multicriteria Detector SIL2 with Speech
V-430-SP-VADW	Multicriteria Detector with Speech and White Beacon
V-530-SP-VADW	Multicriteria Detector SIL2 with Speech and White Beacon
V-430-SP-VADR	Multicriteria Detector with Speech and Red Beacon
V-530-SP-VADR	Multicriteria Detector SIL2 with Speech and Red Beacon
V-430-S-VADR	Multicriteria Detector with Sounder and Red Beacon
V-530-S-VADR	Multicriteria Detector SIL2 with Sounder and Red Beacon
V-430-VADR	Multicriteria Detector with Red Beacon
V-530-VADR	Multicriteria Detector SIL2 with Red Beacon
V-430	Multicriteria Detector
V-530	Multicriteria Detector SIL2
V-530-EXIA	Multicriteria Detector with SIL2 Ex ia
V-530-EXIC	Multicriteria Detector with SIL2 Ex ic
<p>Full model codes are defined by the formats V-430-xxxxx-yy/ww/zz and V-530-xxxxx-yy/ww/zz where:</p> <p>xxxxx = Model as listed in the table above:  S, VADW, VADR, S-VADR, SP-VADW, SP-VADR, EXIA, EXIC</p> <p>yy = Color of housing:  Blank = White, BK = Black, CC = Customized Color</p> <p>ww = Enabled options:  Blank = None, CD = Cover Detection &amp; Self Verify, HS = Extra High Sensitivity*, DS = Data Subscription, CFxxx = Custom Features (C = A to Z, F = A to Z, xxx = 000 to 999)</p> <p>* Note that when the HS = Extra High Sensitivity setting is used, the product is not compliant with EN 54-7:2018.</p>	

Podpis zastopnika/proizvajalca:




Tomasz Dowgiałło, vodja Oddelka za skladnost  
Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim, Norway

SV



# KONFORMITETSDEKLARATION

FÖR



**Produktidentifikation:**


Modell/typ: Se modellista Inledande år för CE-märkning: 2020  
 Kategori (beskrivning): Fire detection and fire alarm systems  
 Märke: Autronica

**Leverantör:** Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim  
 Norway

**EU-representant:** --

Angående	Ett produktprov har testats av	Testrapport-sf-referens	Tillämpade standarder
<b>EMC</b>	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN 61000-6-3:2007+A1:2011+AC:2012 EN 50130-4:2011
<b>CPR</b>	Intertek Deutschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen, Germany	Certificate: 0905-CPR-00840	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010
<b>MED</b>	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: MEDB00006DJ MEDB0000646	EN 54-5:2017+A1:2018 EN 54-7:2018 EN 54-3:2001+A1:2002+A2:2006 EN 54-23:2010 IEC 60092-504:2016 IEC 60533:2015
<b>ATEX</b>	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: DNV 21ATEX14779X (V-530-EXIA) DNV 22ATEX13772X (V-530-EXIC)	EN IEC 60079-0:2018 EN 60079-11:2012
<b>RoHS</b>	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_2022-09-29	EN IEC 63000:2018

**Begränsningar för idrifttagning / krav för användningstillstånd**

Ej tillämpligt  Ingen  

**Konformitetsmetoder**

Vi förklarar under vårt ensamma ansvar att denna produkt överensstämmer med direktiven: 93/68/EEC (märkning), 2014/30/EU (EMC), 305/2011 (CPR), 2014/90/EU (MED), 2014/34/EU (ATEX), och 2011/65/EU (RoHS), ändrad av 2015/863 och 2017/2102, och uppfyller de väsentliga kraven och alla andra relevanta bestämmelser i direktiven baserade på testresultat med användning av harmoniserade standarder i enlighet med nämnda direktiv.

**ATEX:**

V-530-EXIA:  II 1 G Ex ia IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

Representantens/tillverkarens underskrift:



Tomasz Dowgiatto, chef för efterlevnad  
 Autronica Fire & Security AS  
 Bromstadvegen 59,  
 NO-7483 Trondheim, Norway

V-530-EXIC:



II 3 G Ex ic IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C

**Modellista** (Lista över alla produktvarianter eller modeller för vilka denna deklARATION är giltig)

Modell	Beskrivning
V-430-S	Multicriteria Detector with Sounder
V-530-S	Multicriteria Detector SIL2 with Sounder
V-430-VADW	Multicriteria Detector with White Beacon
V-530-VADW	Multicriteria Detector SIL2 with White Beacon
V-430-S-VADW	Multicriteria Detector with Sounder and White Beacon
V-530-S-VADW	Multicriteria SIL2 Detector with Sounder and White Beacon
V-430-SP	Multicriteria Detector with Speech
V-530-SP	Multicriteria Detector SIL2 with Speech
V-430-SP-VADW	Multicriteria Detector with Speech and White Beacon
V-530-SP-VADW	Multicriteria Detector SIL2 with Speech and White Beacon
V-430-SP-VADR	Multicriteria Detector with Speech and Red Beacon
V-530-SP-VADR	Multicriteria Detector SIL2 with Speech and Red Beacon
V-430-S-VADR	Multicriteria Detector with Sounder and Red Beacon
V-530-S-VADR	Multicriteria Detector SIL2 with Sounder and Red Beacon
V-430-VADR	Multicriteria Detector with Red Beacon
V-530-VADR	Multicriteria Detector SIL2 with Red Beacon
V-430	Multicriteria Detector
V-530	Multicriteria Detector SIL2
V-530-EXIA	Multicriteria Detector with SIL2 Ex ia
V-530-EXIC	Multicriteria Detector with SIL2 Ex ic
<p>Full model codes are defined by the formats V-430-xxxxx-yy/ww/zz and V-530-xxxxx-yy/ww/zz where:</p> <p>xxxxx = Model as listed in the table above: S, VADW, VADR, S-VADR, SP-VADW, SP-VADR, EXIA, EXIC</p> <p>yy = Color of housing: Blank = White, BK = Black, CC = Customized Color</p> <p>ww = Enabled options: Blank = None, CD = Cover Detection &amp; Self Verify, HS = Extra High Sensitivity*, DS = Data Subscription, CFxxx = Custom Features (C = A to Z, F = A to Z, xxx = 000 to 999)</p> <p>* Note that when the HS = Extra High Sensitivity setting is used, the product is not compliant with EN 54-7:2018.</p>	

Representantens/tillverkarens underskrift:



Tomasz Dowgiałło, chef för efterlevnad  
Autronica Fire & Security AS  
Bromstadvegen 59,  
NO-7483 Trondheim, Norway

Plats: Gdańsk, Polen

Datum: 30 september 2022

Sida 40 av 40

Dok. Nr: 60. 1005405