

Certificate of constancy of performance,

0832-CPR-F1264

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

AutroSense Micra 25 High Sensitivity Aspirating Smoke Detector
(For full product details and conditions of use refer to appendix)

Produced by or for

Autronica Fire and Security AS

Haakon VII's gt.4
N-7483 Trondheim
Norway

and produced in the manufacturing plant(s)

UTC CCS Manufacturing Polska SP. z.o.o

Ul. Kolejowa 24
39-100 Ropczyce
Poland

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-20:2006 Aspirating smoke detectors

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 19 November 2015 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



Martin McCullagh, Certification Manager
On behalf of BRE Global Limited
Date of issue: 19 November 2015
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.

Appendix to Certificate of constancy of performance 0832-CPR- F1264

Notes:

1. For compliance with Clause 5.10 of EN 54-20:2006, the detector shall be supplied with power from a power supply complying with EN 54-4.
2. The approval of the detector is conditional upon the following requirements:
 - a) Design, installation and commissioning are performed in accordance with the system design manual and instructions.
 - b) The device is approved for sensitivity Classes A, B and C for sensitivities up to 0.31%/m. The Class of any pipe/hole configuration and detector sensitivity must be determined using PipeCAD.



Martin McCullagh, Certification Manager
On behalf of BRE Global Limited
Date of issue: 19 November 2015
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.