

CERTIFICATE OF CONSTANCY OF PERFORMANCE

Issued by DBI Certification, notified body No. 2531.

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

BF-500V2/EX, BF-500V2/N, BF-510WP-H, BF-300-V2

The product fulfils the essential characteristic:

See Annex 1

Intended use: Applications related to automatic fire alarm systems

Placed on the market under the name or trade mark of:

**Autronica Fire and Security AS
Bromstadvegen 59
NO-7047 Trondheim
Norway**

and produced in the manufacturing plant:

CPA10061

This attests that all provisions concerning the performance described in Annex ZA of the standard(s)

EN 54-11:2001/A1:2005 : **Fire detection and fire alarm systems - Part 11: Manual call points**
EN 54-17:2005/AC:2007 : **Fire detection and fire alarm systems - Part 17: Short-circuit isolators**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

CONSTANCY OF PERFORMANCE OF THE CONSTRUCTION PRODUCT.

This certificate was first issued on 2022-09-06 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The attached annexes form part of this certificate.

Date of issue: **2024-04-12.**

(This certificate supersedes the previous version of this certificate issued 2022-09-06)



Merete Poulsen
Responsible for evaluation



Chris Ellis
Responsible for certification decision

Annex 1

EXTENT

Type:		
BF-500V2/EX: Type A (indoor) Manual call point with integrated short circuit isolator BF-500V2/N: Type A ((indoor) Manual call point with integrated short circuit isolator BF-510WP-H: Type A (outdoor) Manual call point with integrated short circuit isolator BF-300-V2: Type A (indoor) Manual call point with integrated short circuit isolator		
Performance		
Essential characteristics	Clauses in EN 54-11:2001	Performance
Nominal activation conditions/Sensitivity, Response delay (response time) and Performance under fire conditions	4.3.2, 4.4, 4.7.1, 4.7.4, 5.2, 5.3	Pass
Operational reliability	4.2, 4.3.1, 4.5, 4.6, 4.7.2, 4.7.3, 4.7.5, 4.8, 5.4, 5.5	Pass
Durability of operational reliability and response delay; temperature resistance	5.7, 5.8 ^a , 5.9	Pass
Durability of operational reliability; vibration resistance	5.14 to 5.17	Pass
Durability of operational reliability; humidity resistance	5.10, 5.11 ^b , 5.12, 5.19 ^c	Pass
Durability of operational reliability; corrosion resistance	5.11, 5.13	Pass
Durability of operational reliability; electrical stability	5.6, 5.18	Pass
a) Outdoor Devices only b) Outdoor Devices only c) Outdoor Devices only		
Essential characteristics	Clauses in EN 54-17:2005	Performance
Performance under fire conditions	5.2 ^{d)}	Pass
Operational reliability	4	Pass
Durability of operational reliability; temperature resistance	5.4, 5.5	Pass
Durability of operational reliability; vibration resistance	5.9 to 5.12	Pass
Durability of operational reliability; humidity resistance	5.6, 5.7	Pass
Durability of operational reliability; corrosion resistance	5.8	Pass
Durability of operational reliability; electrical stability	5.3, 5.13	Pass
d) This is assuming that the effect of the fire is to cause a short circuit in the transmission path that is protected by these devices		

Annex 2

TEST DOCUMENTATION

Accredited Laboratory	Report no.	Date
CNPP	DE 08 00 70	2008-12-23
CNPP	DE 08 00 71	2008-12-23
CNPP	DE 08 00 72	2008-12-23
CNPP	DE 08 00 73	2008-12-23
CNPP	DE 08 00 70 A	2008-12-23
CNPP	DE 08 00 71 A	2008-12-23
CNPP	DE 08 00 72 A	2008-12-23
CNPP	DE 08 00 73 A	2008-12-23

TECHNICAL BASIS

File Number	Title
BoM BF-300V2	Bill of Materials Report
BoM BF-500V2_EX	Bill of Materials Report
BoM BF-510WP-H	Bill of Materials Report
BOM BF-500V2/N	Bill of Materials Report