



Certificate of Compliance

FIRE PROTECTION EQUIPMENT

This certificate is issued for the following equipment:

Models BF-500V2/EX, BF-510WP-H, BF-300V2 Manual Stations

Approval Guide Listing Category: Electrical Signaling, Alarm Signal Initiating Devices, Manual Stations

Non-coded Manual Fire Alarm Stations for use with FM Approved AutoSafe and Autoprime BS-200 Modular Fire Alarm Controls. Autronica Fire and Security AS Models BF-500V2/EX, BF-510WP-H, BF-300V2. Contacts rated 2A at 30V dc. Indoor use only.

Approved For: Autronica Fire and Security AS
Haakon VII's Gate 4
N 7483 Trondheim
Norway

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Approval Report(s), of the following FM Approval Standards and other documents:

<i>Approval Standards</i>	<i>Date</i>	<i>Other Standards</i>	<i>Date</i>
<i>Class Number</i>		<i>Organization, Designation</i>	
		ANSI/UL38	1999
		NFPA 72	2002

Original Approval Job Identification: 3051984

Approval Granted: March 17, 2014

Related Report: None

Subsequent Revisions: None

To verify the availability of the Approved product, please refer to www.approvalguide.com

A handwritten signature in dark ink, appearing to read 'J.E. Marquedant'.

James E. Marquedant
Manager - Electrical Systems
FM Approvals
1151 Boston-Providence Turnpike,
Norwood MA, 02062 USA

23 September 2014

Date



Member of the FM Global Group