Certificate No.: 8504-UKCA-CPR-UKCSP10207



CERTIFICATE OF CONSTANCY OF PERFORMANCE

Issued by DBI Certification-UK, approved body No. 8504.

In compliance with UK STATUTORY INSTRUMENT 2020 No. 1359 Construction Products Regulation 2011 (retained EU law EUR 305/2011) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the construction product

BN-221/01 and BN-221/02

The product fulfils the essential characteristic:

See Annex 1

Applications related to automatic fire alarm systems Intended use:

Placed on the market under the name or trade mark of:

Autronica Fire and Security AS

Bromstadvegen 59 NO-7047 Trondheim

Norway

and produced in the manufacturing plant:

CPA10058

This attests that all provisions concerning the performance described in Annex ZA of the standard(s)

EN 54-17:2005+AC:2007 Fire detection and fire alarm systems — Part 17: Short circuit isolators Fire detection and fire alarm systems — Part 18: Input/output devices EN 54-18:2005+AC:2007

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

CONSTANCY OF PERFORMANCE OF THE CONSTRUCTION PRODUCT.

This certificate was first issued on 2022-10-19 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The attached annexes form part of this certificate.

Date of issue: 2022-10-19.

Steen Nilsson Responsible for evaluation Merete Poulsen

Responsible for certification decision



Certificate No.: 8504-UKCA-CPR-UKCSP10207



Annex 1

EXTENT

Type:

Input/Output Devices with Short-Circuit Isolator

Product	Brand	Туре
Extinguishing Control Unit	Autronica	BN-221/01
Monitored Output Unit	Autronica	BN-221/02

Performance

Essential characteristics	Clauses in EN 54-17:2005/AC:2007	Performance	Notes
Performance under fire conditions	5.2	Pass	1)
Operational reliability	4	Pass	2), 3), 4), 5)
Durability of operational reliability;	5.4, 5.5	Pass	
temperature resistance			
Durability of operational reliability;	5.9 to 5.12	Pass	
vibration resistance			
Durability of operational reliability;	5.6, 5.7	Pass	
humidity resistance			
Durability of operational reliability;	5.8	Pass	
corrosion resistance			
Durability of operational reliability;	5.3, 5.13	Pass	6)
electrical stability			

- 1) This is assuming that the effect of the fire is to cause a short circuit in the transmission path that is protected by these devices
- 2) No integrated visual indicator for indication of the status of the short-circuit isolator. Clause 4.2 are therefore not applicable.
- 3) The short-circuit isolator has no provisions for connections of ancillary devices. Clause 4.3 are therefore not applicable.
- 4) The short-circuit isolator is not detachable. Clause 4.4 are therefore not applicable.
- 5) There is no provision for adjustments. Clause 4.6 are therefore not applicable.
- 6) The unit is supplied from the detection loop, which provides a stable supply from the CIE Therefore the clause 5.3 is not applicable.

Essential characteristics	Clauses in EN 54-18:2005/AC:2007	Performance
Response delay (response time)	5.2 ¹⁾	Pass
Performance under fire conditions	5.1.4	Pass
Operational reliability	5.1.4	Pass
Durability of operational reliability; temperature resistance	5.3, 5.4	Pass
Durability of operational reliability; vibration resistance	5.8 to 5.11	Pass
Durability of operational reliability; humidity resistance	5.5, 5.6	Pass
Durability of operational reliability; corrosion resistance	5.7	Pass
Durability of operational reliability; electrical stability	5.2 ¹⁾ , 5.12	Pass CIE. Therefore the clause F 2 is not applicable.

1) The unit is supplied from the detection loop, which provides a stable supply from the CIE – Therefore the clause 5.2 is not applicable.



No. 23

Certificate No.: 8504-UKCA-CPR-UKCSP10207



Annex 2

TEST DOCUMENTATION

Accredited Laboratory	Report no.	Date
Nemko	E16024.00	2017-01-13
Nemko	E16026.00	2017-01-13
Nemko	E16025.00	2017-01-13
Nemko	E16007.00	2017-01-13
Nemko	E16007.01	2017-01-18

Annex 3

TECHNICAL BASIS

File Number	Title
BoM 116-BN-221.01	Bill of Materials Report
BoM 116-BN-221.02	Bill of Materials Report



DBI Certification-UK Ltd.



Version 2022-02-08 Page **3** of **3**