

CERTIFICATE OF CONSTANCY OF PERFORMANCE

Issued by DBI Certification-UK, approved body No. 8504.

In compliance with UK STATUTORY INSTRUMENT 2020 No. 1359 Construction Products Regulation 2011 (retained EU law EUR 305/2011) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the construction product

BN-300, BN-500/EX, BN-500/N, BN-310, BN-320, BN-320/2, BN-320/4, BN-320/5

The product fulfils the essential characteristic:

See Annex 1

Intended use:

Applications related to automatic fire alarm systems

Placed on the market under the name or trade mark of:

**Autronica Fire and Security AS
Bromstadvegen 59
NO-7047 Trondheim
Norway**

and produced in the manufacturing plant:

CPA10058

This attests that all provisions concerning the performance described in Annex ZA of the standard(s)

EN 54-17:2005+AC:2007 : Fire detection and fire alarm systems — Part 17: Short circuit isolators

EN 54-18:2005+AC:2007 : Fire detection and fire alarm systems — Part 18: Input/output devices

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

CONSTANCY OF PERFORMANCE OF THE CONSTRUCTION PRODUCT.

This certificate was first issued on 2023-09-21 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The attached annexes form part of this certificate.

Date of issue: **2023-09-21**.



Merete Poulsen
Responsible for evaluation



Chris Ellis
Responsible for certification decision

DBI Certification-UK Ltd.

Unit 1 & 2, Northcot Park, Station Road, Blockley, Gloucestershire GL56 9LH
E-mail: info@dbicertification.co.uk · www.dbicertification.co.uk



Annex 1

EXTENT

Type:
Input/Output function with short circuit isolators of the following devices:
BN-300, BN-500/EX, BN-500/N, BN-310, BN-320, BN-320/2, BN-320/4, BN-320/5

Performance

Essential characteristics	Clauses in EN 54-17:2005/AC:2007	Performance	Notes
Performance under fire conditions	5.2	Pass	1)
Operational reliability	4	Pass	
Durability of operational reliability; temperature resistance	5.4, 5.5	Pass	
Durability of operational reliability; vibration resistance	5.9 to 5.12	Pass	
Durability of operational reliability; humidity resistance	5.6, 5.7	Pass	
Durability of operational reliability; corrosion resistance	5.8	Pass	
Durability of operational reliability; electrical stability	5.3, 5.13	Pass	

1) This is assuming that the effect of the fire is to cause a short circuit in the transmission path that is protected by these devices.

Essential characteristics	Clauses in EN 54-18:2005/AC:2007	Performance	Notes
Response delay (response time)	5.2	NPD	1), 2), 3)
Performance under fire conditions	5.1.4	Pass	
Operational reliability	5.1.4	Pass	
Durability of operational reliability; temperature resistance	5.3, 5.4	Pass	
Durability of operational reliability; vibration resistance	5.8 to 5.11	Pass	
Durability of operational reliability; humidity resistance	5.5, 5.6	Pass	4)
Durability of operational reliability; corrosion resistance	5.7	NPD	
Durability of operational reliability; electrical stability	5.2, 5.12	Pass	

1) Response delays may not be a function of the input/output device, in which case no assessment is made as part of this standard.
 2) NPD, not tested with the upper and lower limits of the supply parameters specified by the Manufacturer.
 3) The unit is supplied from the detection loop, which provides a stable supply from the CIE – Therefore the clause 5.2 is not applicable.
 4) The components have been tested for Damp heat, steady state – endurance in the EN 54-17:2005/AC:2007 but not considering the I/O function.

DBI Certification-UK Ltd.

Unit 1 & 2, Northcot Park, Station Road, Blockley, Gloucestershire GL56 9LH
 E-mail: info@dbicertification.co.uk · www.dbicertification.co.uk



Annex 2

TEST DOCUMENTATION

Accredited Laboratory	Report no.	Date
DNV (Applica)	2001-3252	2001-07-12
NEMKO	E18217.00	2018-11-15
ANPI	BFS/REDI/234	2009-01-28
CNPP	DE080070A	2028-12-23

Annex 3

TECHNICAL BASIS

File Number	Title	Date
Doc-1011316 rev 1	I/O Units Performances and Reports cross reference	2023-09-06