



The manufacturer may use the mark:



Revision 3.5 Sept 19, 2025
Surveillance Audit Due
October 1, 2028



Certificate / Certificat Zertifikat / 合格証

AUT 1409202 C002

exida hereby confirms that the:

HC800 Infrared Gas Detector Autronica Fire and Security AS Trondheim - Norway

Has been assessed per the relevant requirements of:

IEC 61508 : 2010 Parts 1-3

and meets requirements providing a level of integrity to:

Systematic Capability: SC 2 (SIL 2 Capable)

Random Capability: Type B Element

SIL 2 @ HFT=0; Route 2_H

**PFD_{avg} and Architecture Constraints
must be verified for each application**

Safety Function:

The line-of-sight infrared Gas Detection System will sense gas concentrations present between the transmitter and receiver components, and signal an alarm on the 4-20mA output (mA output only model), or one or both optional Alarm relay outputs, to indicate the potentially dangerous condition (mA output with optional relay model)

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.



Fabrice Hardy
Evaluating Assessor

Valeria Motto
Certifying Assessor

AUT 1409202 C002

Systematic Capability: SC 2 (SIL 2 Capable)**Random Capability: Type B Element****SIL 2 @ HFT=0; Route 2_H****PFD_{avg} and Architecture Constraints
must be verified for each application**HC800 Infrared
Gas Detector**Systematic Capability:**

The Product has met manufacturer design process requirements of Safety Integrity Level (SIL) 2. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer. A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element. This element meets *exida* criteria for Route 2_H.

IEC 61508 Failure Rates in FIT*

Application/Device/Configuration	λ_{SD}	λ_{SU}	λ_{DD}	λ_{DU}
HC800 (mA)	49	78	1620	72
HC800 (Relay)	224	76	1234	126

* FIT = 1 failure / 10⁹ hours**SIL Verification:**

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFD_{avg} considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

Assessment Report: AUT 14-09-202 R002 V3R3**Safety Manual:** 95-8749-1.1 (HC800 Safety) (or later)80 N Main St
Sellersville, PA 18960