

CERTIFICATE OF CONFORMITY

1. FIRE PROTECTION EQUIPMENT

2. **Certificate No:** FM23FPUS0231
3. **Equipment:** Non-Coded Manual Fire Alarm Stations
(Type Reference and Name)
4. **Name of Listing Company:** Autronica Fire and Security AS
5. **Address of Listing Company:** Bromstadveien 59, Trondheim, Norway
6. The examination and test results are recorded in confidential report number:

3051984 dated 17th March 2014

7. FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

FM 3150:2023

8. This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.

9. Approval Guide Listing Category:

Alarm Signal Initiating Devices, Manual Stations

Certificate issued by:



J.E. Marquedant
VP, Manager - Electrical Systems

12 October 2023

Date

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

F 320 (Jan 23)



CERTIFICATE OF CONFORMITY

US Certificate of Conformity No: FM23FPUS0231



Member of the FM Global Group

10. Description of Equipment:

Non-coded Manual Fire Alarm Stations for use with FM Approved AutoSafe and Autoprime BS-200 Modular Fire Alarm Controls. Autronica Fire and Security AS Models BF-500V2/EX, BF-500V2/N, BF-501, BF-501/EX, BF-501/N, BF-502, BF-502/N, BF-503, BF-503/EX, BF-503/N, BF-510WP-H, BF-300V2. Contacts rated 2A at 30V dc. Indoor use only.

11. Test and Assessment Procedure and Conditions:

This Certificate has been issued in accordance with FM Approvals US Certification Requirements.

12. Schedule Drawings

A copy of the technical documentation has been kept by FM Approvals.

13. Certificate History

Details of the supplements to this certificate are described below:

Date	Description
12 October 2023	Original Issue. Reference RR238087

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

F 320 (Jan 23)



Page 2 of 2