

EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Certificate no.:
MEDB00006DJ
Revision no.:
2

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED), issued as "Forskrift om Skipsutstyr" by the Norwegian Maritime Authority. This Certificate is issued by DNV AS under the authority of the Government of Norway.

This is to certify:

that the **Fixed fire detection and fire alarm systems components for control stations, service spaces, accommodation spaces, cabin balconies, machinery spaces and unattended machinery spaces: - smoke detectors: point detectors using scattered light, transmitted light or ionization**

with type designation(s)
Interactive fire detectors

issued to

Autronica Fire and Security AS
Trondheim, Norway

is found to comply with the Implementing Regulation (EU) 2024/1975 for
Item no. **MED/3.51d (Row 1 of 1)**
according to the following requirements:

SOLAS 74 Reg. II-2/7, IMO Res. MSC.36(63)-(1994 HSC Code) 7, IMO Res. MSC.97(73)-(2000 HSC Code) 7, IMO Res. MSC.391(95)-(IGF Code) 11, IMO MSC.1/Circ.1242, SOLAS 74 Reg. X/3, IMO Res.MSC.98(73)-(FSS Code) 9


Further details of the equipment and conditions for certification are given overleaf.

Date of issue: **2025-05-14**

Expiry date: **2030-05-13**

DNV local unit:
Trondheim

Approval Engineer:
Ståle Sneen



Notified Body
no.: **0575**



for **DNV AS**

Digitally Signed By:
Permota, Jowita
on behalf of

Christine Mydlak-Röder
Head of Notified Body



The mark of conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-surveillance module (D, E or F) of Annex B of the MED is fully complied with and controlled by a written inspection agreement with a Notified Body. The product liability rests with the manufacturer or his representative in accordance with Directive 2014/90/EU.
This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV AS of any changes to the approved equipment. This certificate remains valid unless suspended, withdrawn, recalled or cancelled.
Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to USD 300 000.

Product description

Interactive fire detectors designed according to EN 54 for use with Autronica's interactive fire detection systems:

BH-200 (Note 1)	Smoke detector without SelfVerify
BH-300 (Note 1)	Smoke detector with SelfVerify
BH-500 (Note 1)	Smoke detector with SelfVerify, environmentally protected
BH-500/N (Note 1)	Smoke detector with SelfVerify, Exic-version for use in zone 2 only
BH-500/EX (Note 1)	Smoke detector with SelfVerify, Exia-version for use in all zones
BH-220 (Note 1)	Multisensor detector without SelfVerify
BH-320 (Note 1)	Multisensor detector with SelfVerify
BH-520 (Note 1)	Multisensor detector with SelfVerify, environmentally protected
BH-520/N (Note 1)	Multisensor detector with SelfVerify, Exic-version for use in zone 2 only
BH-520/EX (Note 1)	Multisensor detector with SelfVerify, Exia-version for use in all zones
V-430 (Note 2)	AutroGuard® Multicriteria protector
V-430-S (Note 2)	AutroGuard® Multicriteria protector with sounder
V-430-VADW (Note 2)	AutroGuard® Multicriteria protector with white VAD (visual alarm device)
V-430-VADR (Note 2)	AutroGuard® Multicriteria protector with red VAD
V-430-S-VADW (Note 2)	AutroGuard® Multicriteria protector with sounder and white VAD
V-430-S-VADR (Note 2)	AutroGuard® Multicriteria protector with sounder and red VAD
V-430-S-CO	AutroGuard® Multicriteria protector with sounder and integrated CO sensor
V-530 (Note 3)	AutroGuard® Multicriteria protector with SIL2 approval
V-530-S-VADW (Note 4)	AutroGuard® Multicriteria protector with SIL2 approval with sounder and white VAD
V-530-EXIA (Note 3)	AutroGuard® Multicriteria protector with SIL2 approval, intrinsically safe for zone 0, 1 and 2
V-530-EXIC (Note 3)	AutroGuard® Multicriteria protector with SIL2 approval, intrinsically safe for zone 2
V-530-S-CO	AutroGuard® Multicriteria protector with sounder and integrated CO sensor, ex, SIL

Note 1: The detector head carries an additional H in the name. The listed products include the mandatory socket BWA-100.

Note 2: Available with option for Cover Detection & SelfVerify (option /CD). Tested with base V-100.

Note 3: EXIA/EXIC is available with option for High Sensitivity (option /HS). Tested with base V-110 and V-120.

Note 4: SIL2 certification is for detection only, not for sounder and white VAD functions.

Application/Limitation

Please see Appendix: Application/Limitation

Type Examination documentation

Please see Appendix: Type Examination Documentation

Tests carried out

Applicable tests according to:

- EN 54-3:2014 incl. A1:2019 (for optional sounder),
- EN 54-5:2017 incl. A1:2018 (for multisensor/multicriteria),
- EN 54-7:2018,
- EN 54-17:2005 incl. AC:2007 (for base),
- EN 54-23:2010 (for optional VAD),
- EN 54-29:2015 (for multisensor/multicriteria),
- IEC 60092-504:2016,
- IEC 60533:2015.

Marking of product

For identification to this type examination certificate the products shall be marked with:

- Manufacturer's name or trade mark
- Type designation
- Mark of Conformity (wheel mark), followed by
 - identification number of the NoBo involved in production control (MED D)
 - the year the mark is affixed
 - Example: 0575/2025

APPENDIX

Type Examination documentation

Certificate no.:
MEDB00006DJ
Revision no.:
2

Document No.	Rev.	Title
BFS/DE/1057	-	Report: ANPI, No. BFS/DE/1057-1999.12.09 incl. Add.1-2000-02-25, EN54-5, EN54-7, Misc. equipment
103874656LHD-024	1 / 2020-03-20	Intertek Test Report 103874656LHD-024 - EN 54-29
Doc-1018910	5 / 2024-11-25	Data sheet: V-430-S-CO
Doc-1028938	1 / 2024-09-02	Report: CNOP-PIB, No. 332/BA/24, EN54-7:2018, V-430-S-CO
Doc-1004670	1 / 2021-02-18	Report: Intertek, No. 103874656LHD-025, IEC60092-504:2016, V-430
Doc-1004671	1 / 2020-11-20	Report: Intertek, No. 103963397LHD-021, EN 54-3:2014+A1:2019, V-430
Doc-1004672	1 / 2020-11-20	Report: Intertek, No. 103963397LHD-022, EN54-23:2010, V-430
Doc-1004673	1 / 2020-03-20	Report: Intertek, No. 103874656LHD-023, EN54-17:2005+AC:2007, V-430
Doc-1004675	1 / 2020-03-20	Report: Intertek, No. 103874656LHD-021, EN54-5:2017+A1:2018, V-430
Doc-1004676	1 / 2020-03-20	Report: Intertek, No. 103874656LHD-022, EN54-7:2018, V-430
Doc-1004840	1 / 2018-11-15	Report: Nemko, No. E18217.00, IEC60092-504:2016 (supplemental), Misc. equipment
Doc-1005134	1 / 2000-03-13	Report: DNV, No. 2000-1178 Rev.2, Misc. equipment
Doc-1005355	1 / 2008-06-20	Report: ANPI, No. BFS/REDI/154 Add.1, EN54-5/A1, EN54-7/A2, EN54-7/A2
Doc-1005355	1 / 2009-04-22	Report: ANPI, No. BFS/REDI/154 Add.2, EN54-5:2000, EN54-7:2000, BHH-300, BHH-320, BWA-100
Doc-1005355	1 / 2005-06-03	Report: ANPI, No. BFS/REDI/154, EN54-5:2000, EN54-7:2000, BHH-300, BHH-320, BWA-100
Doc-1010873	1 / 2000-01-04	Report: DNV, No. 99-1491 Rev.2, IACS UR E10 Rev.2; AutoSafe
Doc-1000008	1 / 2019-03-28	Data sheet: BH-500/EX
Doc-1000010	1 / 2019-03-28	Data sheet: BH-520/EX
Doc-1000011	1 / 2021-11-23	Data sheet: BH-500/N
Doc-1000012	1 / 2021-11-23	Data sheet: BH-520/N
Doc-1000337	1 / 2009-06-24	Data sheet: BH-200
Doc-1000339	1 / 2021-08-05	Data sheet: BH-220
Doc-1000341	1 / 2009-06-25	Data sheet: BH-300
Doc-1000343	1 / 2009-06-24	Data sheet: BH-320
Doc-1000345	1 / 2009-06-25	Data sheet: BH-500
Doc-1000353	1 / 2021-08-05	Data sheet: BH-520
Doc-1004270	5 / 2024-12-18	Data sheet: V-100
Doc-1004271	5 / 2024-12-18	Data sheet: V-110, V-120
Doc-1004268	6 / 2025-02-10	Data sheet: V-430 series
Doc-1004269	7 / 2025-02-10	Data sheet: V-530 series

APPENDIX

Application/Limitation

Certificate no.:
MEDB00006DJ
Revision no.:
2

The equipment is found to comply with following location/application dependent requirements
(for definition of each of the location classes, see below the table):

MODEL	TEMPERATURE	VIBRATION	EMC	ENCLOSURE
BH-200	TEM-D	VIB-B	EMC-B	ENC-B
BH-300	TEM-D	VIB-B	EMC-B	ENC-B
BH-500	TEM-D	VIB-B	EMC-B	ENC-B
BH-500/N	TEM-D	VIB-B	EMC-B	ENC-B
BH-500/EX	TEM-D	VIB-B	EMC-B	ENC-B
BH-220	TEM-D	VIB-B	EMC-B	ENC-B
BH-320	TEM-D	VIB-B	EMC-B	ENC-B
BH-520	TEM-D	VIB-B	EMC-B	ENC-B
BH-520/N	TEM-D	VIB-B	EMC-B	ENC-B
BH-520/EX	TEM-D	VIB-B	EMC-B	ENC-B
V-430	TEM-D	VIB-A	EMC-B	ENC-B
V-430-S	TEM-D	VIB-A	EMC-B	ENC-B
V-430-VADW	TEM-D	VIB-A	EMC-B	ENC-B
V-430-VADR	TEM-D	VIB-A	EMC-B	ENC-B
V-430-S-VADW	TEM-D	VIB-A	EMC-B	ENC-B
V-430-S-VADR	TEM-D	VIB-A	EMC-B	ENC-B
V-430-S-CO	TEM-D	VIB-A	EMC-B	ENC-B
V-530	TEM-D	VIB-A	EMC-B	ENC-B
V-530-S-VADW	TEM-D	VIB-A	EMC-B	ENC-B
V-530-EXIA	TEM-D	VIB-A	EMC-B	ENC-B
V-530-EXIC	TEM-D	VIB-A	EMC-B	ENC-B
V-530-S-CO	TEM-D	VIB-A	EMC-B	ENC-B

Definition of the location classes with reference to relevant standards:

- Temperature: TEM-D – Location (-25°C-70°C) (ref. IEC 60092-504:2016 table 1 item 6-7)
- Vibration: VIB-A – For general applications (ref. IEC 60092-504:2016 table 1 item 10)
VIB-B – On reciprocating machines etc. (ref. IEC 60092-504:2016 table 1 item 10)
- EMC: EMC-B – Bridge and open deck zone (ref. IEC 60092-504:2016 table 1 item 13-20)
- Enclosure: ENC-B – Engine room (IP44) (ref. IEC 60092-201:1994 table 5)

Ex installations to be approved in each case according to the Rules and Ex-Certification/ Special Condition for Safe Use listed in valid Ex-certificate issued by a notified/recognized Certification Body.

Ex-certification is not covered by this certificate and the following paragraph, which is for information only, is based on information received from the manufacturer, but not verified by DNV.

Information on Ex-Certification received from manufacturer – Not verified by DNV				
Equipment	Certified			Certificate No.
BHH-500/EX BHH-520/EX	II 1G	Ex ia IIC T5 Ga	Ta: -20°C to +70°C	Nemko 03ATEX218X
BHH-500/N BHH-520/N	II 3G	Ex ic IIB T4 Gc	Ta: -20°C to +70°C	Nemko 03ATEX217X
V-530-EXIA V-530-EXIA/HS	II 1 G	Ex ia IIC T5 Ga	Ta: -30°C to +70°C	DNV 21 ATEX 14779X
V-530-EXIC V-530-EXIC/HS	II 3 G	Ex ic IIB T5 Gc	Ta: -30°C to +70°C	DNV 22 ATEX 13772X