



Certificate of Conformity

| Certificate num. | Registration date | Version | Valid until | |
|-------------------|-------------------|--------------|---------------------------|-------------|
| afp - 2759 | 9-Mar-2012 | Number 14 | Issue date 19-Feb-2026 | 30-Apr-2027 |

Product designation

AutroSafe 4, fire alarm and control system

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Kidde Australia
Suite 4.01, 2 Ferntree Place, NOTTING HILL, VIC, AUSTRALIA, 3168

Registrant

Autronica Fire and Security AS
Bromstadvegen 59, TRONDHEIM, NORWAY, NO-7047

Producer

Autronica Fire and Security AS
Bromstadvegen 59, TRONDHEIM, NORWAY, NO-7047

Conformance criteria and evaluation

The AutroSafe 4, fire alarm and control system has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS 7240.2-2004, 'Fire detection and alarm systems - Part 2: Control and indicating equipment (ISO 7240-2:2003, MOD)'.
2. Australian Standard AS 7240.4-2004, 'Fire detection and alarm systems - Part 4: Power supply equipment (ISO 7240-4:2003, MOD)'.
3. Australian Standard AS 7240.13-2006, 'Fire detection and alarm systems - Part 13: Compatibility assessment of system components'.
4. ActivFire Technical Specification AF-TS002, Version 1.0, 23-Jan-2012, 'Input/Output modules for control and indicating equipment'.
5. Australian Standard AS 4428.3-2010, 'Fire detection, warning, control and intercom systems - Control and indicating equipment - Fire brigade panel'.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

Kaj Loh
Executive Officer – ActivFire Scheme



Schedule to Certificate of Conformity

| | | | | |
|-------------------|-------------------|--------------|---------------------------|-------------|
| Certificate num. | Registration date | Version | Valid until | |
| afp - 2759 | 9-Mar-2012 | Number 14 | Issue date 19-Feb-2026 | 30-Apr-2027 |
| | | | | Page 2 of 4 |

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- i. Compatibility of this equipment with new or existing actuating devices should be verified prior to installation.
- ii. The installation of this equipment shall be in areas appropriate to the lower audible indication level as contemplated in AS 7240.2-2004, clause 13.10.2.

Producer's description

The AutoSafe 4, fire alarm and control system, provides advanced functionality within fire detection for a wide range of applications.

The system is designed to meet requirements in the high-end segment of the land, maritime and offshore market.

The AutoSafe 4, fire alarm and control system operates on a high-speed and fully redundant Ethernet based network solution; AutoNet, providing extremely fast data transmission. A maximum of 64 system units (panels, controllers) can be connected to the AutoNet. A standalone system is also possible, using the Fire Alarm Control Panel BS-420 (the mandatory panel in any system).

The system has a large capacity, and the fact that all types of loop units can be connected to the same detection loop gives large flexibility.

Technical specification

The following details are a representative extract of the technical specification for the AutoSafe 4, fire alarm and control system and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

1. Schedule of designated system components

The AutoSafe 4, fire alarm and control system comprises of a number of modules, as detailed below, which mount into the c.i.e. housing or are field mountable.

| System component designation | | | Modules included | Conformance criteria |
|------------------------------|-----------|----------------------------|--|----------------------------------|
| Ident. type | Ident. | Component type | | |
| Product name (Model) | BS-420 | Fire Alarm Control Panel | BSE-310 – Input Module, monitored BSB-310 – Output Module, monitored BSD-310– Loop Driver Module BSL-310- Communication Module BSS-310A – Power Supply Module FL Switch 8TX – 10/100 MBit/s eight Port Ethernet Switch FL Switch 8TX – 10/100 MBit/s eight Port Ethernet Switch BSA-400 – Main board BSR-400 – Front board | AS 7240.2-2004 |
| | BS-420G | | | |
| | BS-420G2 | | | |
| | BS-420M | | | |
| | | | BU-110AUS – Fire brigade loop panel | AS 4428.3-2010 AS 7240.2-2004 |
| Product name (Model) | BC-420 | Controller | BSE-320 – Input Module BSJ-310 – Output Module BSD-310– Loop Driver Module BSL-310- Communication Module BSS-310A – Power Supply Module BSA-400 – Main board BSR-400 – Front board | AS 7240.2-2004 |
| Part num. | BN-221/01 | Extinguishing Control Unit | BNA-221 | AS 7240.2-2004 |
| Part num. | BN-221/02 | Monitored Output Unit | BNA-221 | AS 7240.2-2004 |
| Product name (Model) | BP-405 | Power Cabinet | BPS-405 – Power Unit BSF-400 – Main board MeanWell SC-150-27ME – Power Supply | AS 7240.4-2004 |
| Part num. | BN-300 | Input Unit | BNB-300 | AF-TS002 |
| | BN-310 | Single Relay Output Unit | BNA-320 | AF-TS002 |

Schedule to Certificate of Conformity

| | | | | |
|-------------------|-------------------|--------------|---------------------------|-------------|
| Certificate num. | Registration date | Version | Valid until | |
| afp - 2759 | 9-Mar-2012 | Number 14 | Issue date 19-Feb-2026 | 30-Apr-2027 |

2. Schedule of designated system software

| Software version | Description |
|------------------|---|
| 4.12.0 | AutoSafe software version 4.12.0, including new features, improvements and bug fixes. |

3. Schedule of I/O modules with extended compatibility details

| System component designation | | | Type | Maximum number of devices per addressable loop * | Conformance criteria |
|------------------------------|----------|--|------|--|-----------------------------|
| Ident. type | Ident. | Component type | | | |
| Part num. | BN-303 | Single Monitored Input Unit | 1 | 127 | AS 7240.13-2006 AF-TS002 |
| | BN-304 | Single Monitored Input/Output Unit | | | |
| | BN-305 | Dual Monitored Input/Output Unit | | | |
| | BN-305-2 | Dual Monitored Input/Output Unit | | | |
| | BN-307 | Monitored Fire Alarm Device Control Unit | | | |
| | BNB-331 | Conventional Interface Unit | | | |
| | BZ-500 | Galvanic Isolator Barrier Unit | | 60 | |

* Maximum number of detectors allowed by loop. Installation standard (AS 1670.1-2004) limits the maximum number of devices per loop to 1000, with a maximum of 40 detectors for one zone.

4. Specified properties for c.i.e. and p.s.e. modules

BP-405

The Power Cabinet BP-405 provides space for two 12 Vdc / 18 Ah batteries (not included). The maximum available power is 24 Vdc / 5 A.

| | |
|-----------------------|--|
| Dimensions (mm) | 420 x 346 x 146 |
| Protection class | IP32 |
| Operating Temperature | -15 to +70°C |
| Current | 230VAC 1,6A |
| Input voltage range | 184 – 264 VAC (47 – 63 Hz) |
| Output | 3.5 A (max load) 5 A (max load without batteries) |
| Battery size | 7.2 Ah (min) 18 Ah (max) |

BS-420

BS-420 is a complete fire alarm control panel with full operating capabilities. The panel serves as an operating panel for one or several operation zones.

All alarm handling and system features can be controlled and monitored from the panel.

The fire alarm control panel is available in three different variants specifically designed for the land market (BS-420), maritime market (BS-420M) and petrochemical oil & gas market (BS-420G).

| | |
|------------------------|---------------------------|
| Dimensions (mm) | 350 x 350 x 161 |
| Protection class | IP32 |
| Operating Temperature: | -15 to 70 °C |
| Power supply | Nom. 27.2V DC (18-32V DC) |

BC-420

The Controller serves as a connection unit for Loop Driver Modules and I/O modules.

| | |
|------------------------|---------------------------|
| Dimensions (mm) | 350 x 350 x 161 |
| Protection class | IP32 |
| Operating Temperature: | -15 to 70 °C |
| Power supply | Nom. 27.2V DC (18-32V DC) |

5. Schedule of optional functions with requirements

The following schedule of AS 7240.2–2004 optional functions with requirements have been validated.

| | |
|----|-------------------------------------|
| 1. | Indications: |
| a. | Fault signals from points (Cl. 9.3) |
| 2. | Controls: |
| a. | Disabled condition (Cl. 10) |

Schedule to Certificate of Conformity

| | | | | |
|-------------------|-------------------|--------------|---------------------------|-------------|
| Certificate num. | Registration date | Version | Valid until | |
| afp - 2759 | 9-Mar-2012 | Number 14 | Issue date 19-Feb-2026 | 30-Apr-2027 |

- b. Disabling of each addressable points (Cl. 10.5)
- c. Test condition (Cl. 11)
- 3. Outputs:
 - a. Output to fire alarm devices (Cl. 7.8)
 - b. Control of fire alarm routing equipment (Cl. 7.9)
 - c. Output to fire protection equipment (Cl. 7.10) *see Note 1
 - d. Output to fault warning routing equipment (Cl. 9.9)
- 4. Operational
 - a. Impact (operational) (Cl. 16.6, Annex ZA2: not optional)
 - b. Vibration, sinusoidal (operational) (Cl. 16.7, Annex ZA2: not optional)
 - c. Dry Heat, Steady State (Operational) (Cl. Annex ZC)
- 5. Marking requirements (Cl. 15, Annex ZA2: not optional)

Note 1: Output to Fire Protection Equipment may be provided by either BSB-310, BN-221/01 or BN-221/02.

The following schedule of AS 7240.4–2004 optional functions with requirements have been validated.

- 1. Battery function check (Cl. 5.5)
- 2. Marking (Cl.8, Annex ZA2: not optional)
- 3. Impact (operational) (Cl. 9.7, Annex ZA2: not optional)
- 4. Vibration, sinusoidal (operational) (Cl. 9.8, Annex ZA2: not optional)
- 5. Vibration, sinusoidal (endurance) (Cl. 9.11, Annex ZA2: not optional)

Supplementary information

Schedule of relevant articles

The following schedule is an extract of articles significant and/or related as evidence of conformity.

| Reference | | Title / description | Date issued (or date validated) | Source |
|-------------|--------------------------------|--|------------------------------------|------------------------------------|
| Ident. type | Ident. | | | |
| Report | CSBA0240/VR1A | Verification of Conformity of the Autronica, AutoSafe 4 fire alarm and control system to Australian Standard AS 7240.2:2004, 'Fire detection and alarm systems – Part 2: Fire detection control and indicating equipment – Clause 14 | 16-Feb-2026 | CSIRO, Fire Systems Laboratory, AU |
| | XF2887/R1 | Compatibility Assessment of the Autronica Input/Output modules and AutoSafe 4, fire alarm and control system to the requirements of AS 7240.13-2006 | 4-Nov-2015 | |
| | XF2875/R1 | Evaluation for Conformity of the Autronica BU-110AUS Fire Brigade Loop Panel to the requirements of AS 7240.2-2004 and AS 4428.3-2010 | 26-Aug-2015 | |
| | XF2709/R1 | Conformity Evaluation of the AutoSafe 4 Fire Detection System to the requirements of AS 7240.2 2004 and AS 7240.4 2004 | 7-Mar-2012 | |
| | XF2709/R2 | Conformity Evaluation of the AutoSafe BN 300 and BN 310 I/O Modules to the requirements of ActivFire Technical Specification AF TS002 Issue 1.0 | 23-Feb-2012 | |
| Extract | Syst Desc asafesystemd_egb.pdf | System Description AutoSafe Interactive Fire Detection System Doc-1004720-2, 2024-03-18, Autronica Fire And Security AS (Syst Desc asafesystemd_egb.pdf) | 18-Mar-2024 | Autronica Fire and Security AS, NO |
| | AutroSafe_SW_relnotes.pdf | AUTRONICA Release Notes AutoSafe Interactive Fire Detection System AutoSafe Software 4.12.0 (AutroSafe_SW_relnotes.pdf) | 11-Jul-2024 | |